

THE CITY OF TAYLORSVILLE
2600 West Taylorsville Boulevard (5320 South)
Taylorsville, UT 84118

Request for Proposals
HVAC Upgrades Taylorsville Fire Station 118 – Apparatus Bay
Due April 7, 2010, at 3:00 p.m.

PROJECT DESCRIPTION AND REQUIREMENTS

1. **Introduction.** The City of Taylorsville (the “City”) is requesting proposals (“Proposals” or “Responses”) from qualified manufacturers, suppliers, and installers (“Proposers”) to provide HVAC upgrades for the Fire Station 118 apparatus bay for the City of Taylorsville (or its designee) (the “Project”).

1.1. **Intent.** It is the intent of this Request for Proposals (this “Request”) to set forth the minimum acceptable requirements for Responses to this Request.

2. **Project Description.** The City is requesting proposals from Proposers to provide appropriately sized “Coolerado” (or equivalent) units to cool the fire station apparatus bay, including relief air openings, water connections, and electrical connections. The City would like to have a solar panel option to run the “Coolerado” (or equivalent) units.

2.1. **Detailed Description of Project.** Fire station facilities operate 24 hours per day every day of the year. Given such extended operating hours, it is common that fire stations are one of the largest consumers of energy in the City’s facility portfolio.

The fire apparatus bay at Station 118 is not currently climate controlled. Plans of Station 118 are attached as Exhibit “C”. During summer months, the intense heat (130 degrees at ground level) can cause equipment malfunctions. These malfunctions include computerized response and life safety equipment. This public safety hazard has been deemed inappropriate. The current method of dealing with the problem is to use the CO2 exhaust fans to circulate air. The hourly rate of consumption for this piece of equipment is 1.8 kW/h. Natural airflow by opening up bay doors presents a security risk and is not a preference for the station. The proposed solution is the installation of appropriately sized “Coolerado” or equivalent systems. Proposals shall include all costs for providing material and complete installation, including relief air openings, water connections, and electrical connections. Proposals must include a solar panel option to run the “Coolerado” (or equivalent) units.

The selected proposer will assist the City by providing completed forms, applications, calculations, etc. required to obtain any available incentives or credits from manufacturers and or utility providers.

2.2. **Warranty.** The Proposer must include a warranty against defects in materials, workmanship, and performance HVAC upgrades for five (5) years on materials and one (1) year on labor after installation is accepted by the City. The warranty must provide that

any material item that fails due to defects in materials, workmanship, or performance within the warranty period shall be replaced by the Proposer without charge to the City. Proposer may, at the Proposer's expense, maintain records and claim any refund that may be applicable under the manufacturer's warranty.

3. **Schedule.** All products covered under this Project shall be delivered and installed within sixty (60) calendar days after the date of the Contract described below.

4. **Identification of Anticipated Potential Problems.** Proposals should identify and describe any potential problems with respect to the Project.

5. **Proposal Requirements.** One (1) unbound original and six (6) copies of Responses are required to be submitted to the City as listed below no later than 3:00 p.m. on April 7, 2010. Guidelines for Responses are described in exhibit "A" attached hereto. Any response, modification, or amendment received after the due date and time is late. No late Responses will be accepted. Responses may be modified or withdrawn prior to the due date and time, provided any such request is submitted to the City as listed below in writing prior to the due date and time. No electronic (facsimile, e-mail, or telegraphic) Responses, request to modify, or request to withdraw will be accepted. Proposals must include the following elements and be signed by an authorized representative of the Proposer.

Please be informed that the Project is being funded by the Energy Efficiency and Conservation Block Grant Program – Formula Grants ("Grant") and special terms and conditions may be applicable. Submission of a Response shall be deemed a representation of the Proposers that they understand the special terms and conditions of the Grant and that the Response complies with all of the terms and conditions of the Grant.

6. **Evaluation Criteria and Scoring Process.** All Proposals received will be reviewed by a Review Panel (defined below). The cost alone will not be the sole determining factor in the selection of the products for this Project. The City will consider the Price or Cost, Specifications, Qualifications, Delivery Schedule, Aesthetic Considerations, References, and Product Certifications to form the basis for its decision on which Proposer will be selected.

Each evaluation criterion has been given a percentage based on its relative value as a whole. The criteria and each associated percentage are as follows:

<u>Evaluation Criteria</u>	<u>Weight</u>
Qualifications	10%
Specifications	15%
Delivery Schedule	5%
Aesthetic Considerations	5%
References	5%
Product Certifications	5%
Price	55%
Total	100%

7. **Selection.** Discussions may be conducted with Proposers determined by the City to be reasonably susceptible of being selected for the award. In addition, one or more Proposers

may be invited to interview. Provided however, Proposals may be accepted without discussion or interview. The above criteria will be used unless modified in the interview evaluation. A selection committee or individual(s) will be appointed by the City (referred to hereinafter as "Review Panel"). The Review Panel reserves the right to modify the interview criteria during the course of this process. If such modification occurs, each Proposer being interviewed will be notified at least twenty-four (24) hours prior to the interview of the revised criteria. Based on the results of discussions, if any, interviews, if any, and proposal scoring, the Proposers will be rated by the Review Panel, and such recommendations will be forwarded to the Mayor. The Mayor will make the final selection. The Mayor may select one or more Proposers to participate in the Project.

8. **General Information.** The City reserves the right to reject any and all Responses. The City reserves the right to amend, modify, or waive any requirement set forth in this Request. Response to this Request is at the Proposer's sole risk and expense. All Responses must comply with applicable federal, state, and local laws and regulations. Except for written responses provided by the contact person described below, the City has not authorized anyone to make any representations regarding the subject matter of this Request. All requests for clarification or additional information regarding this Request must be submitted in writing to the contact person described below no later than March 30, 2010, at 3:00 p.m. The contact person will endeavor to respond to such request for clarification or additional information and if the contact person deems, in his sole and absolute discretion, that such response is of general applicability, his response, if any, will be posted on the City's website at <http://www.taylorsvilleut.gov> (which constitutes a written response). Entities responding to this Request are encouraged to review such website frequently. The City anticipates selecting one or more of the responding Proposers, but there is no guaranty that any responding Proposer will be selected.

Responses will be placed in the public domain and become public records subject to examination and review by any interested parties in accordance with the Government Records Access Management Act (UTAH CODE ANN. § 63-2-101, et seq.). All materials submitted in response to this Request will become the property of the City and will be managed in accordance with the Government Records Access Management Act.

9. **Terms of Contract.** The successful Proposer will be required to enter into a written agreement with the City with respect to the Project. If the selected Proposer and the City attorneys' office are unable to negotiate an acceptable agreement, then another Proposer(s) will be selected by the Mayor and negotiation will continue with such other Proposer(s) until an acceptable agreement is completed.

10. **Contact Person.** For further information or for Americans with Disabilities Act (ADA) accommodation, or questions pertaining to the Project shall be addressed in writing to Donald Adams at dadams@taylorsvilleut.gov (801) 963- 5400, 2600 West Taylorsville Boulevard, Taylorsville, Utah 84118.

Exhibit "A"

[Guidelines]

PROPOSAL SUBMITTAL PROCEDURE

1. **The Proposer shall submit the proposal in accordance with the following requirements:**

- **Required documents to be submitted:**
 - a. Proposal Schedule
 - b. Proposer/Products Qualifications and References
 - c. Documentation of the specifications, testing, and other performance measures of the proposed products.
 - d. A table of bulb/fixture/adaptor/ancillary supply by type, quantity, unit cost, and total cost shall be provided.
- **The proposal shall be valid for a minimum of 90 days.**
- **The proposal shall be addressed to:**

City of Taylorsville
City Administrator's Office
CITY OF TAYLORSVILLE
2600 West Taylorsville Blvd.
Taylorsville, UT 84118

2. **Notice of Use of Federal Funds**
This project is funded using the ENERGY EFFICIENCY AND CONSERVATION BLOCK GRANT PROGRAM – FORMULA GRANTS (EECBG).

The City is required to conform to and all Proposals are subject to SPECIAL TERMS AND CONDITIONS FOR THE ENERGY EFFICIENCY AND CONSERVATION BLOCK GRANT PROGRAM – FORMULA GRANTS as set forth in Exhibit "B."

3. Number Responses sequentially on the upper right hand corner of the cover.
Color is allowed.
8-1/2" x 11" page sizes.
Paginate pages.
One (1) inch margins (exceptions: Consultant Name/Logo and Page Headers/Footers may be within the margin).
Size 12 Font.
Except for unbound copy, bind Responses on left side.
Provide tabs for each section of the Response.
Front and back cover pages.

Exhibit "B"

[SPECIAL TERMS AND CONDITIONS FOR THE ENERGY EFFICIENCY AND
CONSERVATION BLOCK GRANT PROGRAM – FORMULA GRANTS]

**SPECIAL TERMS AND CONDITIONS FOR THE ENERGY EFFICIENCY AND CONSERVATION
BLOCK GRANT PROGRAM – FORMULA GRANTS**

Table of Contents

1.	RESOLUTION OF CONFLICTING CONDITIONS.....	1
2.	AWARD AGREEMENT TERMS AND CONDITIONS.....	1
3.	AWARD PROJECT PERIOD AND BUDGET PERIODS.....	1
4.	STAGED DISBURSEMENT OF FUNDS.....	1
5.	PAYMENT PROCEDURES - ADVANCES THROUGH THE AUTOMATED STANDARD APPLICATION FOR PAYMENTS (ASAP) SYSTEM.....	2
6.	INCREMENTAL FUNDING AND MAXIMUM OBLIGATION - COEXTENSIVE BUDGET PERIOD AND PROJECT PERIOD.....	2
7.	COST SHARING FFRDC'S NOT INVOLVED.....	2
8.	REBUDGETING AND RECOVERY OF INDIRECT COSTS.....	3
9.	CEILING ON ADMINISTRATIVE COSTS.....	4
10.	LIMITATIONS ON USE OF FUNDS.....	4
11.	PRE-AWARD COSTS.....	4
12.	USE OF PROGRAM INCOME - ADDITION.....	4
13.	STATEMENT OF FEDERAL STEWARDSHIP.....	4
14.	SITE VISITS.....	5
15.	REPORTING REQUIREMENTS.....	5
16.	PUBLICATIONS.....	5
17.	FEDERAL, STATE, AND MUNICIPAL REQUIREMENTS.....	6
18.	INTELLECTUAL PROPERTY PROVISIONS AND CONTACT INFORMATION.....	6
19.	LOBBYING RESTRICTIONS.....	6
20.	NOTICE REGARDING THE PURCHASE OF AMERICAN-MADE EQUIPMENT AND PRODUCTS - - SENSE OF CONGRESS.....	6
21.	INSOLVENCY, BANKRUPTCY OR RECEIVERSHIP.....	6
22.	NATIONAL ENVIRONMENTAL POLICY ACT (NEPA) REQUIREMENTS.....	6
23.	DECONTAMINATION AND/OR DECOMMISSIONING (D&D) COSTS.....	7
24.	SPECIAL PROVISIONS RELATING TO WORK FUNDED UNDER AMERICAN RECOVERY AND REINVESTMENT ACT OF 2009 (MAY 2009).....	7
25.	REPORTING AND REGISTRATION REQUIREMENTS UNDER SECTION 1512 OF THE RECOVERY ACT (MAY 2009).....	11
26.	REQUIRED USE OF AMERICAN IRON, STEEL, AND MANUFACTURED GOODS -- SECTION 1605 OF THE AMERICAN RECOVERY AND REINVESTMENT ACT OF 2009 (MAY 2009).....	11
27.	REQUIRED USE OF AMERICAN IRON, STEEL, AND MANUFACTURED GOODS (COVERED UNDER INTERNATIONAL AGREEMENTS)--SECTION 1605 OF THE AMERICAN RECOVERY AND REINVESTMENT ACT OF 2009 (MAY 2009).....	13
28.	WAGE RATE REQUIREMENTS UNDER SECTION 1606 OF THE RECOVERY ACT (MAY 2009).....	16
29.	RECOVERY ACT TRANSACTIONS LISTED IN SCHEDULE OF EXPENDITURES OF FEDERAL AWARDS AND RECIPIENT RESPONSIBILITIES FOR INFORMING SUBRECIPIENTS (MAY 2009).....	17
30.	DAVIS BACON ACT REQUIREMENTS (MAY 2009).....	18
31.	HISTORIC PRESERVATION.....	25
	<u>ATTACHMENT 1 – INTELLECTUAL PROPERTY PROVISIONS.....</u>	<u>26</u>

**SPECIAL TERMS AND CONDITIONS FOR THE ENERGY EFFICIENCY AND
CONSERVATION BLOCK GRANT PROGRAM – FORMULA GRANTS**

1. RESOLUTION OF CONFLICTING CONDITIONS

Any apparent inconsistency between Federal statutes and regulations and the terms and conditions contained in this award must be referred to the DOE Award Administrator for guidance.

2. AWARD AGREEMENT TERMS AND CONDITIONS

This award/agreement consists of the Grant and Cooperative Agreement cover page, plus the following:

- a. Special terms and conditions.
- b. Attachments:

<u>Attachment No.</u>	<u>Title</u>
1	Intellectual Property Provisions
2	Project Activity Worksheet(s) are attached. If the Worksheet is for the Strategy, the grant will be amended to include additional Worksheets as activities are approved.
3	Federal Assistance Reporting Checklist
4	Budget Pages are attached. For Strategy, the SF-424A is attached, if it was included in the application. The grant will be amended to include additional Budget Pages as activities are approved.
5	Davis-Bacon Act Wage Determination(s), if applicable. For Strategy awards, the Wage Determination will be included when activities are approved.
6	Special Requirements, if applicable

- c. Applicable program regulations: Title V, Subtitle E of the Energy Independence Security Act (EISA) of 2007, Public Law 110-140.
- d. DOE Assistance Regulations, 10 CFR Part 600 at <http://ecfr.gpoaccess.gov> and if the award is for research and to a university or non-profit, the Research Terms & Conditions and the DOE Agency Specific Requirements at <http://www.nsf.gov/bfa/dias/policy/rtc/index.jsp>.
- e. Application/proposal as approved by DOE.
- f. National Policy Assurances to Be Incorporated as Award Terms in effect on date of award at http://management.energy.gov/business_doe/1374.htm

3. AWARD PROJECT PERIOD AND BUDGET PERIODS

The Project and Budget Periods for this award are concurrent for a 36-month period as indicated in Item No. 7 of the Assistance Agreement Face Page.

4. STAGED DISBURSEMENT OF FUNDS

[] IF MARKED, THIS TERM IS APPLICABLE

The total funding allocation for this award is shown in Block 13 of the Assistance Agreement Cover Page. However, funds will be released according to a staged disbursement schedule. All funds must be expended within 36 months of the effective date of the award.

For Energy Efficiency Conservation Strategy (EECS) Only awards, funds in the amount of \$ is released to the Recipient to begin work on the EECS. The approved activities are listed in Attachment 2, Project Activity Worksheets. The remaining funds will be released for disbursement upon DOE approval of the EECS and amendment of the award to include the authorized Project Activity Worksheets.

Funds in the amount of \$ is released to the Recipient to begin work on the activities listed in Attachment 2, Project Activity Worksheets. The remaining funds will be released for disbursement upon DOE approval of additional activities and amendment of the award to include the authorized Project Activity Worksheets.

Funds in the amount of \$ is released to the Recipient to begin work on administrative duties pending resolution of problematic issues such as eligibility, technical issues, NEPA, historic preservation, budgetary items, or similar issues. The remaining funds will be released upon successful resolution of these issues and amendment of the award.

5. PAYMENT PROCEDURES - ADVANCES THROUGH THE AUTOMATED STANDARD APPLICATION FOR PAYMENTS (ASAP) SYSTEM

IF MARKED, THIS TERM DOES NOT APPLY - SEE ATTACHMENT 6

- a. Method of Payment. Payment will be made by advances through the Department of Treasury's ASAP system.
- b. Requesting Advances. Requests for advances must be made through the ASAP system. You may submit requests as frequently as required to meet your needs to disburse funds for the Federal share of project costs. If feasible, you should time each request so that you receive payment on the same day that you disburse funds for direct project costs and the proportionate share of any allowable indirect costs. If same-day transfers are not feasible, advance payments must be as close as is administratively feasible to actual disbursements.
- c. Adjusting payment requests for available cash. You must disburse any funds that are available from repayments to and interest earned on a revolving fund, program income, rebates, refunds, contract settlements, audit recoveries, credits, discounts, and interest earned on any of those funds before requesting additional cash payments from DOE/NNSA.
- d. Payments. All payments are made by electronic funds transfer to the bank account identified on the ASAP Bank Information Form that you filed with the U.S. Department of Treasury.

6. INCREMENTAL FUNDING AND MAXIMUM OBLIGATION - COEXTENSIVE BUDGET PERIOD AND PROJECT PERIOD

APPLICABLE ONLY TO INCREMENTALLY FUNDED AWARDS.

This award is funded on an incremental basis. The maximum obligation of the DOE/NNSA is limited to the amount shown on the Agreement Face Page. You are not obligated to continue performance of the project beyond the total amount obligated and your pro rata share of the project costs, if cost sharing is required. Additional funding is contingent upon the availability of appropriated funds and substantial progress towards meeting the objectives of the award.

7. COST SHARING FFRDC'S NOT INVOLVED

APPLICABLE ONLY IF COST SHARING IS INCLUDED IN THE AWARD.

- a. Total Estimated Project Cost is the sum of the Government share and Recipient share of the estimated

project costs. The Recipient's cost share must come from non-Federal sources unless otherwise allowed by law. By accepting federal funds under this award, you agree that you are liable for your percentage share of total allowable project costs, on a budget period basis, even if the project is terminated early or is not funded to its completion. This cost is shared as follows:

Budget Period No.	Budget Period Start	Government Share \$/%	Recipient Share \$/%	Total Estimated Cost
Total Project				

- b. If you discover that you may be unable to provide cost sharing of at least the amount identified in paragraph a of this article, you should immediately provide written notification to the DOE Award Administrator indicating whether you will continue or phase out the project. If you plan to continue the project, the notification must describe how replacement cost sharing will be secured.
- c. You must maintain records of all project costs that you claim as cost sharing, including in-kind costs, as well as records of costs to be paid by DOE/NNSA. Such records are subject to audit.
- d. Failure to provide the cost sharing required by this Article may result in the subsequent recovery by DOE/NNSA of some or all the funds provided under the award.

8. REBUDGETING AND RECOVERY OF INDIRECT COSTS

THE APPLICABLE TERM IS MARKED BELOW.

REBUDGETING AND RECOVERY OF INDIRECT COSTS - REIMBURSABLE INDIRECT COSTS AND FRINGE BENEFITS

- a. If actual allowable indirect costs and fringe benefits are less than those budgeted and funded under the award, you may use the difference to pay additional allowable direct costs during the project period. If at the completion of the award the Government's share of total allowable costs (i.e., direct, indirect, fringe benefits), is less than the total costs reimbursed, you must refund the difference.
- b. Recipients are expected to manage their indirect costs and fringe benefits. DOE will not amend an award solely to provide additional funds for changes in indirect costs and fringe benefits. DOE recognizes that the inability to obtain full reimbursement for indirect costs and fringe benefits means the recipient must absorb the underrecovery. Such underrecovery may be allocated as part of the organization's required cost sharing.

REBUDGETING AND RECOVERY OF INDIRECT COSTS – REIMBURSABLE INDIRECT COSTS

- a. If actual allowable indirect costs are less than those budgeted and funded under the award, you may use the difference to pay additional allowable direct costs during the project period. If at the completion of the award the Government's share of total allowable costs (i.e., direct and indirect), is less than the total costs reimbursed, you must refund the difference.
- b. Recipients are expected to manage their indirect costs. DOE will not amend an award solely to provide additional funds for changes in indirect cost rates. DOE recognizes that the inability to obtain full reimbursement for indirect costs means the recipient must absorb the underrecovery. Such underrecovery may be allocated as part of the organization's required cost sharing.
- c. The budget for this award includes indirect costs, but does not include fringe benefits. Therefore, fringe benefit costs shall not be charged to nor shall reimbursement be requested for

this project nor shall the fringe benefit costs for this project be allocated to any other federally sponsored project. In addition, fringe benefit costs shall not be counted as cost share unless approved by the Contracting Officer.

[X] **REBUDGETING AND RECOVERY OF INDIRECT COSTS - INDIRECT COSTS AND FRINGE BENEFITS ARE NOT REIMBURSABLE**

The budget for this award does not include indirect costs or fringe benefits. Therefore, these expenses shall not be charged to nor reimbursement requested for this project nor shall the fringe and indirect costs from this project be allocated to any other federally sponsored project. In addition, indirect costs or fringe benefits shall not be counted as cost share unless approved by the Contracting Officer.

9. CEILING ON ADMINISTRATIVE COSTS

- a. Recipients may not use more than 10 percent of amounts provided under this program, or \$75,000, whichever is greater (EISA Sec 545(b)(3)(A), for administrative expenses, excluding the costs of meeting the reporting requirements under Title V, Subtitle E of EISA. These costs should be captured and summarized for each activating under the Projected Costs Within Budget: Administration.
- b. Recipients are expected to manage their administrative costs. DOE will not amend an award solely to provide additional funds for changes in administrative costs. The Recipient shall not be reimbursed on this project for any final administrative costs that are in excess of the designated 10 percent administrative cost ceiling. In addition, the Recipient shall neither count costs in excess of the administrative cost ceiling as cost share, nor allocate such costs to other federally sponsored projects, unless approved by the Contracting Officer.

10. LIMITATIONS ON USE OF FUNDS

- a. Recipients may not use more than 20 percent or \$250,000, whichever is greater (EISA Sec 545(b)(3)(B), for the establishment of revolving loan funds.
- b. Recipients may not use more than 20 percent or \$250,000, whichever is greater (EISA Sec 545(b)(3)(C), for subgrants to nongovernmental organizations for the purpose of assisting in the implementation of the energy efficiency and conservation strategy of the eligible unit of local government.

11. PRE-AWARD COSTS

APPLICABLE ONLY IF COMPLETED BELOW.

You are entitled to reimbursement for preaward costs for the period from [MonthDayYear] to [MonthDayYear] in accordance with your request dated [MonthDayYear] if such costs are allowable in accordance with the applicable Federal cost principles referenced in 10 CFR Part 600.

12. USE OF PROGRAM INCOME - ADDITION

If you earn program income during the project period as a result of this award, you may add the program income to the funds committed to the award and use it to further eligible project objectives.

13. STATEMENT OF FEDERAL STEWARDSHIP

DOE/NNSA will exercise normal Federal stewardship in overseeing the project activities performed under this award. Stewardship activities include, but are not limited to, conducting site visits; reviewing performance and financial reports; providing technical assistance and/or temporary intervention in unusual circumstances to correct deficiencies which develop during the project; assuring compliance with terms and

conditions; and reviewing technical performance after project completion to ensure that the award objectives have been accomplished.

14. SITE VISITS

DOE's authorized representatives have the right to make site visits at reasonable times to review project accomplishments and management control systems and to provide technical assistance, if required. You must provide, and must require your subawardees to provide, reasonable access to facilities, office space, resources, and assistance for the safety and convenience of the government representatives in the performance of their duties. All site visits and evaluations must be performed in a manner that does not unduly interfere with or delay the work.

15. REPORTING REQUIREMENTS

- a. Requirements. The reporting requirements for this award are identified on the Federal Assistance Reporting Checklist, DOE F 4600.2, attached to this award. Failure to comply with these reporting requirements is considered a material noncompliance with the terms of the award. Noncompliance may result in withholding of future payments, suspension, or termination of the current award, and withholding of future awards. A willful failure to perform, a history of failure to perform, or unsatisfactory performance of this and/or other financial assistance awards, may also result in a debarment action to preclude future awards by Federal agencies.
- b. Dissemination of scientific/technical reports. Scientific/technical reports submitted under this award will be disseminated on the Internet via the DOE Information Bridge (www.osti.gov/bridge), unless the report contains patentable material, protected data, or SBIR/STTR data. Citations for journal articles produced under the award will appear on the DOE Energy Citations Database (www.osti.gov/energycitations).
- c. Restrictions. Reports submitted to the DOE Information Bridge must not contain any Protected Personal Identifiable Information (PII), limited rights data (proprietary data), classified information, information subject to export control classification, or other information not subject to release.

16. PUBLICATIONS

- a. You are encouraged to publish or otherwise make publicly available the results of the work conducted under the award.
- b. An acknowledgment of Federal support and a disclaimer must appear in the publication of any material, whether copyrighted or not, based on or developed under this project, as follows:

Acknowledgment: "This material is based upon work supported by the Department of Energy under Award Number [*Enter the award number*]."

Disclaimer: "This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

17. FEDERAL, STATE, AND MUNICIPAL REQUIREMENTS

You must obtain any required permits and comply with applicable federal, state, and municipal laws, codes, and regulations for work performed under this award.

18. INTELLECTUAL PROPERTY PROVISIONS AND CONTACT INFORMATION

- a. The intellectual property provisions applicable to this award are provided as an attachment to this award or are referenced on the Agreement Face Page. A list of all intellectual property provisions may be found at http://www.gc.doe.gov/financial_assistance_awards.htm.
- b. Questions regarding intellectual property matters should be referred to the DOE Award Administrator and the Patent Counsel designated as the service provider for the DOE office that issued the award. The IP Service Providers List is found at [http://www.gc.doe.gov/documents/Intellectual_Property_\(IP\)_Service_Providers_for_Acquisition.pdf](http://www.gc.doe.gov/documents/Intellectual_Property_(IP)_Service_Providers_for_Acquisition.pdf)

19. LOBBYING RESTRICTIONS

By accepting funds under this award, you agree that none of the funds obligated on the award shall be expended, directly or indirectly, to influence congressional action on any legislation or appropriation matters pending before Congress, other than to communicate to Members of Congress as described in 18 U.S.C. 1913. This restriction is in addition to those prescribed elsewhere in statute and regulation.

20. NOTICE REGARDING THE PURCHASE OF AMERICAN-MADE EQUIPMENT AND PRODUCTS -- SENSE OF CONGRESS

It is the sense of the Congress that, to the greatest extent practicable, all equipment and products purchased with funds made available under this award should be American-made.

21. INSOLVENCY, BANKRUPTCY OR RECEIVERSHIP

- a. You shall immediately notify the DOE of the occurrence of any of the following events: (i) you or your parent's filing of a voluntary case seeking liquidation or reorganization under the Bankruptcy Act; (ii) your consent to the institution of an involuntary case under the Bankruptcy Act against you or your parent; (iii) the filing of any similar proceeding for or against you or your parent, or its consent to, the dissolution, winding-up or readjustment of your debts, appointment of a receiver, conservator, trustee, or other officer with similar powers over you, under any other applicable state or federal law; or (iv) your insolvency due to your inability to pay your debts generally as they become due.
- b. Such notification shall be in writing and shall: (i) specifically set out the details of the occurrence of an event referenced in paragraph a; (ii) provide the facts surrounding that event; and (iii) provide the impact such event will have on the project being funded by this award.
- c. Upon the occurrence of any of the four events described in the first paragraph, DOE reserves the right to conduct a review of your award to determine your compliance with the required elements of the award (including such items as cost share, progress towards technical project objectives, and submission of required reports). If the DOE review determines that there are significant deficiencies or concerns with your performance under the award, DOE reserves the right to impose additional requirements, as needed, including (i) change your payment method; or (ii) institute payment controls.
- d. Failure of the Recipient to comply with this provision may be considered a material noncompliance of this financial assistance award by the Contracting Officer.

22. NATIONAL ENVIRONMENTAL POLICY ACT (NEPA) REQUIREMENTS

You are restricted from taking any action using Federal funds, which would have an adverse effect on the

environment or limit the choice of reasonable alternatives prior to DOE/NNSA providing either a NEPA clearance or a final NEPA decision regarding this project. Prohibited actions include: Activities not specified below. **Historic preservation clause applies.** This restriction does not preclude you from: 1) Grant administration, 2) hire consultant for professional services, 3) hire consultant to conduct audit and accounting, 4) hot water and plumbing improvements at senior citizens center, 5) HVAC upgrades at senior citizens center, 6) electrical upgrades at all Taylorsville facilities, 7) HVAC upgrades at Bennion Heritage Center, 8) hot water and plumbing improvements at Bennion Heritage Center, 9) hot water and plumbing improvements at city office, 10) HVAC upgrades, thermostats and sensors at Fire Station #118, 11) install a Coolerado at Fire Station #118m 12) convert street lights to LED or induction lighting, and 13) install solar hot water system at Fire Station #118.

If you move forward with activities that are not authorized for federal funding by the DOE Contracting Officer in advance of the final NEPA decision, you are doing so at risk of not receiving federal funding and such costs may not be recognized as allowable cost share.

If this award includes construction activities, you must submit an environmental evaluation report/evaluation notification form addressing NEPA issues prior to DOE/NNSA initiating the NEPA process.

23. DECONTAMINATION AND/OR DECOMMISSIONING (D&D) COSTS

Notwithstanding any other provisions of this Agreement, the Government shall not be responsible for or have any obligation to the recipient for (i) Decontamination and/or Decommissioning (D&D) of any of the recipient's facilities, or (ii) any costs which may be incurred by the recipient in connection with the D&D of any of its facilities due to the performance of the work under this Agreement, whether said work was performed prior to or subsequent to the effective date of this Agreement.

24. SPECIAL PROVISIONS RELATING TO WORK FUNDED UNDER AMERICAN RECOVERY AND REINVESTMENT ACT OF 2009 (MAY 2009)

Preamble

The American Recovery and Reinvestment Act of 2009, Pub. L. 111-5, (Recovery Act) was enacted to preserve and create jobs and promote economic recovery, assist those most impacted by the recession, provide investments needed to increase economic efficiency by spurring technological advances in science and health, invest in transportation, environmental protection, and other infrastructure that will provide long-term economic benefits, stabilize State and local government budgets, in order to minimize and avoid reductions in essential services and counterproductive State and local tax increases. Recipients shall use grant funds in a manner that maximizes job creation and economic benefit.

The Recipient shall comply with all terms and conditions in the Recovery Act relating generally to governance, accountability, transparency, data collection and resources as specified in Act itself and as discussed below.

Recipients should begin planning activities for their first tier subrecipients, including obtaining a DUNS number (or updating the existing DUNS record), and registering with the Central Contractor Registration (CCR).

Be advised that Recovery Act funds can be used in conjunction with other funding as necessary to complete projects, but tracking and reporting must be separate to meet the reporting requirements of the Recovery Act and related guidance. For projects funded by sources other than the Recovery Act, Contractors must keep separate records for Recovery Act funds and to ensure those records comply with the requirements of the Act.

The Government has not fully developed the implementing instructions of the Recovery Act, particularly concerning specific procedural requirements for the new reporting requirements. The Recipient will be

provided these details as they become available. The Recipient must comply with all requirements of the Act. If the recipient believes there is any inconsistency between ARRA requirements and current award terms and conditions, the issues will be referred to the Contracting Officer for reconciliation.

Definitions

For purposes of this clause, Covered Funds means funds expended or obligated from appropriations under the American Recovery and Reinvestment Act of 2009, Pub. L. 111-5. Covered Funds will have special accounting codes and will be identified as Recovery Act funds in the grant, cooperative agreement or TIA and/or modification using Recovery Act funds. Covered Funds must be reimbursed by September 30, 2015.

Non-Federal employer means any employer with respect to covered funds – the contractor, subcontractor, grantee, or recipient, as the case may be, if the contractor, subcontractor, grantee, or recipient is an employer; and any professional membership organization, certification of other professional body, any agent or licensee of the Federal government, or any person acting directly or indirectly in the interest of an employer receiving covered funds; or with respect to covered funds received by a State or local government, the State or local government receiving the funds and any contractor or subcontractor receiving the funds and any contractor or subcontractor of the State or local government; and does not mean any department, agency, or other entity of the federal government.

Recipient means any entity that receives Recovery Act funds directly from the Federal government (including Recovery Act funds received through grant, loan, or contract) other than an individual and includes a State that receives Recovery Act Funds.

Special Provisions

A. Flow Down Requirement

Recipients must include these special terms and conditions in any subaward.

B. Segregation of Costs

Recipients must segregate the obligations and expenditures related to funding under the Recovery Act. Financial and accounting systems should be revised as necessary to segregate, track and maintain these funds apart and separate from other revenue streams. No part of the funds from the Recovery Act shall be commingled with any other funds or used for a purpose other than that of making payments for costs allowable for Recovery Act projects.

Prohibition on Use of Funds

None of the funds provided under this agreement derived from the American Recovery and Reinvestment Act of 2009, Pub. L. 111-5, may be used by any State or local government, or any private entity, for any casino or other gambling establishment, aquarium, zoo, golf course, or swimming pool.

C. Access to Records

With respect to each financial assistance agreement awarded utilizing at least some of the funds appropriated or otherwise made available by the American Recovery and Reinvestment Act of 2009, Pub. L. 111-5, any representative of an appropriate inspector general appointed under section 3 or 8G of the Inspector General Act of 1988 (5 U.S.C. App.) or of the Comptroller General is authorized –

- (1) to examine any records of the contractor or grantee, any of its subcontractors or subgrantees, or any State or local agency administering such contract that pertain to, and involve transactions relation to, the subcontract, subcontract, grant, or subgrant; and

- (2) to interview any officer or employee of the contractor, grantee, subgrantee, or agency regarding such transactions.

D. Publication

An application may contain technical data and other data, including trade secrets and/or privileged or confidential information, which the applicant does not want disclosed to the public or used by the Government for any purpose other than the application. To protect such data, the applicant should specifically identify each page including each line or paragraph thereof containing the data to be protected and mark the cover sheet of the application with the following Notice as well as referring to the Notice on each page to which the Notice applies:

Notice of Restriction on Disclosure and Use of Data

The data contained in pages ---- of this application have been submitted in confidence and contain trade secrets or proprietary information, and such data shall be used or disclosed only for evaluation purposes, provided that if this applicant receives an award as a result of or in connection with the submission of this application, DOE shall have the right to use or disclose the data here to the extent provided in the award. This restriction does not limit the Government's right to use or disclose data obtained without restriction from any source, including the applicant.

Information about this agreement will be published on the Internet and linked to the website www.recovery.gov, maintained by the Accountability and Transparency Board. The Board may exclude posting contractual or other information on the website on a case-by-case basis when necessary to protect national security or to protect information that is not subject to disclosure under sections 552 and 552a of title 5, United States Code.

E. Protecting State and Local Government and Contractor Whistleblowers

The requirements of Section 1553 of the Act are summarized below. They include, but are not limited to:

Prohibition on Reprisals: An employee of any non-Federal employer receiving covered funds under the American Recovery and Reinvestment Act of 2009, Pub. L. 111-5, may not be discharged, demoted, or otherwise discriminated against as a reprisal for disclosing, including a disclosure made in the ordinary course of an employee's duties, to the Accountability and Transparency Board, an inspector general, the Comptroller General, a member of Congress, a State or Federal regulatory or law enforcement agency, a person with supervisory authority over the employee (or other person working for the employer who has the authority to investigate, discover or terminate misconduct, a court or grand jury, the head of a Federal agency, or their representatives information that the employee believes is evidence of:

- gross management of an agency contract or grant relating to covered funds;
- a gross waste of covered funds
- a substantial and specific danger to public health or safety related to the implementation or use of covered funds;
- an abuse of authority related to the implementation or use of covered funds; or
- as violation of law, rule, or regulation related to an agency contract (including the competition for or negotiation of a contract) or grant, awarded or issued relating to covered funds.

Agency Action: Not later than 30 days after receiving an inspector general report of an alleged reprisal, the head of the agency shall determine whether there is sufficient basis to conclude that the non-Federal employer has subjected the employee to a prohibited reprisal. The agency shall either issue an order denying relief in whole or in part or shall take one or more of the following actions:

- Order the employer to take affirmative action to abate the reprisal.
- Order the employer to reinstate the person to the position that the person held before the reprisal,

together with compensation including back pay, compensatory damages, employment benefits, and other terms and conditions of employment that would apply to the person in that position if the reprisal had not been taken.

- Order the employer to pay the employee an amount equal to the aggregate amount of all costs and expenses (including attorneys' fees and expert witnesses' fees) that were reasonably incurred by the employee for or in connection with, bringing the complaint regarding the reprisal, as determined by the head of a court of competent jurisdiction.

Nonenforceability of Certain Provisions Waiving Rights and remedies or Requiring Arbitration: Except as provided in a collective bargaining agreement, the rights and remedies provided to aggrieved employees by this section may not be waived by any agreement, policy, form, or condition of employment, including any predispute arbitration agreement. No predispute arbitration agreement shall be valid or enforceable if it requires arbitration of a dispute arising out of this section.

Requirement to Post Notice of Rights and Remedies: Any employer receiving covered funds under the American Recovery and Reinvestment Act of 2009, Pub. L. 111-5, shall post notice of the rights and remedies as required therein. (Refer to section 1553 of the American Recovery and Reinvestment Act of 2009, Pub. L. 111-5, www.Recovery.gov, for specific requirements of this section and prescribed language for the notices.).

F. Request for Reimbursement

Reserved

G. False Claims Act

Recipient and sub-recipients shall promptly refer to the DOE or other appropriate Inspector General any credible evidence that a principal, employee, agent, contractor, sub-grantee, subcontractor or other person has submitted a false claim under the False Claims Act or has committed a criminal or civil violation of laws pertaining to fraud, conflict of interest, bribery, gratuity or similar misconduct involving those funds.

H. Information in supporting of Recovery Act Reporting

Recipient may be required to submit backup documentation for expenditures of funds under the Recovery Act including such items as timecards and invoices. Recipient shall provide copies of backup documentation at the request of the Contracting Officer or designee.

I. Availability of Funds

Funds appropriated under the Recovery Act and obligated to this award are available for reimbursement of costs until September 30, 2015.

J. Additional Funding Distribution and Assurance of Appropriate Use of Funds

Applicable if award is to a State Government or an Agency

Certification by Governor -- Not later than April 3, 2009, for funds provided to any State or agency thereof by the American Reinvestment and Recovery Act of 2009, Pub. L. 111-5, the Governor of the State shall certify that: 1) the state will request and use funds provided by the Act; and 2) the funds will be used to create jobs and promote economic growth.

Acceptance by State Legislature -- If funds provided to any State in any division of the Act are not accepted for use by the Governor, then acceptance by the State legislature, by means of the adoption of a concurrent resolution, shall be sufficient to provide funding to such State.

Distribution – After adoption of a State legislature’s concurrent resolution, funding to the State will be for distribution to local governments, councils of government, public entities, and public-private entities within the State either by formula or at the State’s discretion.

K. Certifications

With respect to funds made available to State or local governments for infrastructure investments under the American Recovery and Reinvestment Act of 2009, Pub. L. 111-5, the Governor, mayor, or other chief executive, as appropriate, certified by acceptance of this award that the infrastructure investment has received the full review and vetting required by law and that the chief executive accepts responsibility that the infrastructure investment is an appropriate use of taxpayer dollars. Recipient shall provide an additional certification that includes a description of the investment, the estimated total cost, and the amount of covered funds to be used for posting on the Internet. A State or local agency may not receive infrastructure investment funding from funds made available by the Act unless this certification is made and posted.

25. REPORTING AND REGISTRATION REQUIREMENTS UNDER SECTION 1512 OF THE RECOVERY ACT (MAY 2009)

- a. This award requires the recipient to complete projects or activities which are funded under the American Recovery and Reinvestment Act of 2009 (Recovery Act) and to report on use of Recovery Act funds provided through this award. Information from these reports will be made available to the public.
- b. The reports are due no later than ten calendar days after each calendar quarter in which the recipient receives the assistance award funded in whole or in part by the Recovery Act.
- c. Recipients and their first-tier recipients must maintain current registrations in the Central Contractor Registration (<http://www.ccr.gov>) at all times during which they have active federal awards funded with Recovery Act funds. A Dun and Bradstreet Data Universal Numbering System (DUNS) Number (<http://www.dnb.com>) is one of the requirements for registration in the Central Contractor Registration.
- d. The recipient shall report the information described in section 1512(c) of the Recovery Act using the reporting instructions and data elements that will be provided online at <http://www.FederalReporting.gov> and ensure that any information that is pre-filled is corrected or updated as needed.

26. REQUIRED USE OF AMERICAN IRON, STEEL, AND MANUFACTURED GOODS -- SECTION 1605 OF THE AMERICAN RECOVERY AND REINVESTMENT ACT OF 2009 (MAY 2009)

THIS AWARD TERM IS APPLICABLE TO ANY RECOVERY ACT FUNDS FOR CONSTRUCTION, ALTERATION, MAINTENANCE, OR REPAIR OF A PUBLIC BUILDING OR PUBLIC WORK AND THE TOTAL PROJECT VALUE IS ESTIMATED LESS THAN \$7,443,000. THIS AWARD TERM ALSO APPLIES TO ALL SUBGRANTS AND CONTRACTS.

- a. Definitions. As used in this award term and condition--
 - (1) Manufactured good means a good brought to the construction site for incorporation into the building or work that has been—
 - (i) Processed into a specific form and shape; or
 - (ii) Combined with other raw material to create a material that has different properties than the properties of the individual raw materials.
 - (2) Public building and public work means a public building of, and a public work of, a governmental

entity (the United States; the District of Columbia; commonwealths, territories, and minor outlying islands of the United States; State and local governments; and multi-State, regional, or interstate entities which have governmental functions). These buildings and works may include, without limitation, bridges, dams, plants, highways, parkways, streets, subways, tunnels, sewers, mains, power lines, pumping stations, heavy generators, railways, airports, terminals, docks, piers, wharves, ways, lighthouses, buoys, jetties, breakwaters, levees, and canals, and the construction, alteration, maintenance, or repair of such buildings and works.

- (3) Steel means an alloy that includes at least 50 percent iron, between .02 and 2 percent carbon, and may include other elements.

b. Domestic preference.

- (1) This award term and condition implements Section 1605 of the American Recovery and Reinvestment Act of 2009 (Recovery Act) (Pub. L. 111--5), by requiring that all iron, steel, and manufactured goods used in the project are produced in the United States except as provided in paragraph (b)(3) and (b)(4) of this section and condition.

- (2) This requirement does not apply to the material listed by the Federal Government as follows:

None

[Award official to list applicable excepted materials or indicate "none"]

- (3) The award official may add other iron, steel, and/or manufactured goods to the list in paragraph (b)(2) of this section and condition if the Federal Government determines that--
- (i) The cost of the domestic iron, steel, and/or manufactured goods would be unreasonable. The cost of domestic iron, steel, or manufactured goods used in the project is unreasonable when the cumulative cost of such material will increase the cost of the overall project by more than 25 percent;
 - (ii) The iron, steel, and/or manufactured good is not produced, or manufactured in the United States in sufficient and reasonably available quantities and of a satisfactory quality; or
 - (iii) The application of the restriction of section 1605 of the Recovery Act would be inconsistent with the public interest.

c. Request for determination of inapplicability of Section 1605 of the Recovery Act .

(1)

(i) Any recipient request to use foreign iron, steel, and/or manufactured goods in accordance with paragraph (b)(3) of this section shall include adequate information for Federal Government valuation of the request, including--

- (A) A description of the foreign and domestic iron, steel, and/or manufactured goods;
- (B) Unit of measure;
- (C) Quantity;
- (D) Cost;
- (E) Time of delivery or availability;
- (F) Location of the project;
- (G) Name and address of the proposed supplier; and
- (H) A detailed justification of the reason for use of foreign iron, steel, and/or manufactured goods cited in accordance with paragraph (b)(3) of this section.

(ii) A request based on unreasonable cost shall include a reasonable survey of the market and a completed cost comparison table in the format in paragraph (d) of this section.

(iii) The cost of iron, steel, and/or manufactured goods material shall include all delivery costs to the construction site and any applicable duty.

(iv) Any recipient request for a determination submitted after Recovery Act funds have been obligated for a project for construction, alteration, maintenance, or repair shall explain why the recipient could not reasonably foresee the need for such determination

and could not have requested the determination before the funds were obligated. If the recipient does not submit a satisfactory explanation, the award official need not make a determination.

- (2) If the Federal Government determines after funds have been obligated for a project for construction, alteration, maintenance, or repair that an exception to section 1605 of the Recovery Act applies, the award official will amend the award to allow use of the foreign iron, steel, and/or relevant manufactured goods. When the basis for the exception is nonavailability or public interest, the amended award shall reflect adjustment of the award amount, redistribution of budgeted funds, and/or other actions taken to cover costs associated with acquiring or using the foreign iron, steel, and/or relevant manufactured goods. When the basis for the exception is the unreasonable cost of the domestic iron, steel, or manufactured goods, the award official shall adjust the award amount or redistribute budgeted funds by at least the differential established in 2 CFR 176.110(a).
- (3) Unless the Federal Government determines that an exception to section 1605 of the Recovery Act applies, use of foreign iron, steel, and/or manufactured goods is noncompliant with section 1605 of the American Recovery and Reinvestment Act.
- d. Data. To permit evaluation of requests under paragraph (b) of this section based on unreasonable cost, the Recipient shall include the following information and any applicable supporting data based on the survey of suppliers:

Foreign and Domestic Items Cost Comparison

Description	Unit of Measure	Quantity	Cost (dollars)*
<i>Item 1:</i>			
Foreign steel, iron, or manufactured good			
Domestic steel, iron, or manufactured good			
<i>Item 2:</i>			
Foreign steel, iron, or manufactured good			
Domestic steel, iron, or manufactured good			

List name, address, telephone number, email address, and contact for suppliers surveyed. Attach copy of response; if oral, attach summary.

Include other applicable supporting information.

*Include all delivery costs to the construction site.

27. REQUIRED USE OF AMERICAN IRON, STEEL, AND MANUFACTURED GOODS (COVERED UNDER INTERNATIONAL AGREEMENTS)--SECTION 1605 OF THE AMERICAN RECOVERY AND REINVESTMENT ACT OF 2009 (MAY 2009)

THIS AWARD TERM IS APPLICABLE TO ANY RECOVERY ACT FUNDS FOR CONSTRUCTION, ALTERATION, MAINTENANCE, OR REPAIR OF A PUBLIC BUILDING OR PUBLIC WORK WITH A TOTAL PROJECT VALUE OVER \$7,443,000 THAT INVOLVES IRON, STEEL, AND/OR MANUFACTURED GOODS MATERIALS COVERED UNDER INTERNATIONAL AGREEMENTS. THIS AWARD TERM ALSO APPLIES TO ALL SUBGRANTS AND CONTRACTS.

a. Definitions. As used in this award term and condition--

Designated country –

- (1) A World Trade Organization Government Procurement Agreement country (Aruba, Austria, Belgium, Bulgaria, Canada, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hong Kong, Hungary, Iceland, Ireland, Israel, Italy, Japan, Korea (Republic of), Latvia, Liechtenstein, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Singapore, Slovak Republic, Slovenia, Spain, Sweden, Switzerland, and United Kingdom);
- (2) A Free Trade Agreement (FTA) country (Australia, Bahrain, Canada, Chile, Costa Rica, Dominican Republic, El Salvador, Guatemala, Honduras, Israel, Mexico, Morocco, Nicaragua, Oman, Peru, or Singapore); or
- (3) A United States-European Communities Exchange of Letters (May 15, 1995) country: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Poland, Portugal, Romania, Slovak Republic, Slovenia, Spain, Sweden, and United Kingdom.

Designated country iron, steel, and/or manufactured goods –

- (1) Is wholly the growth, product, or manufacture of a designated country; or
- (2) In the case of a manufactured good that consist in whole or in part of materials from another country, has been substantially transformed in a designated country into a new and different manufactured good distinct from the materials from which it was transformed.

Domestic iron, steel, and/or manufactured good –

- (1) Is wholly the growth, product, or manufacture of the United States; or
- (2) In the case of a manufactured good that consists in whole or in part of materials from another country, has been substantially transformed in the United States into a new and different manufactured good distinct from the materials from which it was transformed. There is no requirement with regard to the origin of components or subcomponents in manufactured goods or products, as long as the manufacture of the goods occurs in the United States.

Foreign iron, steel, and/or manufactured good means iron, steel and/or manufactured good that is not domestic or designated country iron, steel, and/or manufactured good.

Manufactured good means a good brought to the construction site for incorporation into the building or work that has been--

- (1) Processed into a specific form and shape; or
- (2) Combined with other raw material to create a material that has different properties than the properties of the individual raw materials.

Public building and public work means a public building of, and a public work of, a governmental entity (the United States; the District of Columbia; commonwealths, territories, and minor outlying islands of the United States; State and local governments; and multi-State, regional, or interstate entities which have governmental functions). These buildings and works may include, without limitation, bridges, dams, plants, highways, parkways, streets, subways, tunnels, sewers, mains, power lines, pumping stations, heavy generators, railways, airports, terminals, docks, piers,

wharves, ways, lighthouses, buoys, jetties, breakwaters, levees, and canals, and the construction, alteration, maintenance, or repair of such buildings and works.

Steel means an alloy that includes at least 50 percent iron, between .02 and 2 percent carbon, and may include other elements.

b. Iron, steel, and manufactured goods.

- (1) The award term and condition described in this section implements--
 - (i) Section 1605(a) of the American Recovery and Reinvestment Act of 2009 (Pub. L. 111--5) (Recovery Act), by requiring that all iron, steel, and manufactured goods used in the project are produced in the United States; and
 - (ii) Section 1605(d), which requires application of the Buy American requirement in a manner consistent with U.S. obligations under international agreements. The restrictions of section 1605 of the Recovery Act do not apply to designated country iron, steel, and/or manufactured goods. The Buy American requirement in section 1605 shall not be applied where the iron, steel or manufactured goods used in the project are from a Party to an international agreement that obligates the recipient to treat the goods and services of that Party the same as domestic goods and services. This obligation shall only apply to projects with an estimated value of \$7,443,000 or more.
- (2) The recipient shall use only domestic or designated country iron, steel, and manufactured goods in performing the work funded in whole or part with this award, except as provided in paragraphs (b)(3) and (b)(4) of this section.
- (3) The requirement in paragraph (b)(2) of this section does not apply to the iron, steel, and manufactured goods listed by the Federal Government as follows:

None

[Award official to list applicable excepted materials or indicate "none"]

- (4) The award official may add other iron, steel, and manufactured goods to the list in paragraph (b)(3) of this section if the Federal Government determines that--
 - (i) The cost of domestic iron, steel, and/or manufactured goods would be unreasonable. The cost of domestic iron, steel, and/or manufactured goods used in the project is unreasonable when the cumulative cost of such material will increase the overall cost of the project by more than 25 percent;
 - (ii) The iron, steel, and/or manufactured good is not produced, or manufactured in the United States in sufficient and reasonably available commercial quantities of a satisfactory quality; or
 - (iii) The application of the restriction of section 1605 of the Recovery Act would be inconsistent with the public interest.
- c. Request for determination of inapplicability of section 1605 of the Recovery Act or the Buy American Act.
- (1) (i) Any recipient request to use foreign iron, steel, and/or manufactured goods in accordance with paragraph (b)(4) of this section shall include adequate information for Federal Government evaluation of the request, including--
 - (A) A description of the foreign and domestic iron, steel, and/or manufactured goods;
 - (B) Unit of measure;
 - (C) Quantity;
 - (D) Cost;
 - (E) Time of delivery or availability;
 - (F) Location of the project;
 - (G) Name and address of the proposed supplier; and

- (H) A detailed justification of the reason for use of foreign iron, steel, and/or manufactured goods cited in accordance with paragraph (b)(4) of this section.
 - (ii) A request based on unreasonable cost shall include a reasonable survey of the market and a completed cost comparison table in the format in paragraph (d) of this section.
 - (iii) The cost of iron, steel, or manufactured goods shall include all delivery costs to the construction site and any applicable duty.
 - (iv) Any recipient request for a determination submitted after Recovery Act funds have been obligated for a project for construction, alteration, maintenance, or repair shall explain why the recipient could not reasonably foresee the need for such determination and could not have requested the determination before the funds were obligated. If the recipient does not submit a satisfactory explanation, the award official need not make a determination.
- (2) If the Federal Government determines after funds have been obligated for a project for construction, alteration, maintenance, or repair that an exception to section 1605 of the Recovery Act applies, the award official will amend the award to allow use of the foreign iron, steel, and/or relevant manufactured goods. When the basis for the exception is nonavailability or public interest, the amended award shall reflect adjustment of the award amount, redistribution of budgeted funds, and/or other appropriate actions taken to cover costs associated with acquiring or using the foreign iron, steel, and/or relevant manufactured goods.. When the basis for the exception is the unreasonable cost of the domestic iron, steel, or manufactured goods, the award official shall adjust the award amount or redistribute budgeted funds, as appropriate, by at least the differential established in 2 CFR 176.110(a).
- (3) Unless the Federal Government determines that an exception to section 1605 of the Recovery Act applies, use of foreign iron, steel, and/or manufactured goods other than designated country iron, steel, and/or manufactured goods is noncompliant with the applicable Act.
- d. Data. To permit evaluation of requests under paragraph (b) of this section based on unreasonable cost, the applicant shall include the following information and any applicable supporting data based on the survey of suppliers:

Foreign and Domestic Items Cost Comparison

Description	Unit of Measure	Quantity	Cost (dollars)*
<i>Item 1:</i>			
Foreign steel, iron, or manufactured good			
Domestic steel, iron, or manufactured good			
<i>Item 2:</i>			
Foreign steel, iron, or manufactured good			
Domestic steel, iron, or manufactured good			

List name, address, telephone number, email address, and contact for suppliers surveyed. Attach copy of response; if oral, attach summary.

Include other applicable supporting information.

*Include all delivery costs to the construction site.

28. WAGE RATE REQUIREMENTS UNDER SECTION 1606 OF THE RECOVERY ACT (MAY 2009)

THIS AWARD TERM IS APPLICABLE TO RECOVERY ACT PROGRAMS OR ACTIVITIES THAT MAY INVOLVE CONSTRUCTION, ALTERATION, MAINTENANCE, OR REPAIR. THIS AWARD TERM ALSO APPLIES TO ALL SUBGRANTS AND CONTRACTS.

- a. Section 1606 of the Recovery Act requires that all laborers and mechanics employed by contractors and subcontractors on projects funded directly by or assisted in whole or in part by and through the Federal Government pursuant to the Recovery Act shall be paid wages at rates not less than those prevailing on projects of a character similar in the locality as determined by the Secretary of Labor in accordance with subchapter IV of chapter 31 of title 40, United States Code.

Pursuant to Reorganization Plan No. 14 and the Copeland Act, 40 U.S.C. 3145, the Department of Labor has issued regulations at 29 CFR parts 1, 3, and 5 to implement the Davis-Bacon and related Acts. Regulations in 29 CFR 5.5 instruct agencies concerning application of the standard Davis-Bacon contract clauses set forth in that section. Federal agencies providing grants, cooperative agreements, and loans under the Recovery Act shall ensure that the standard Davis-Bacon contract clauses found in 29 CFR 5.5(a) are incorporated in any resultant covered contracts that are in excess of \$2,000 for construction, alteration or repair (including painting and decorating).

- b. For additional guidance on the wage rate requirements of section 1606, contact your awarding agency. Recipients of grants, cooperative agreements and loans should direct their initial inquiries concerning the application of Davis-Bacon requirements to a particular federally assisted project to the Federal agency funding the project. The Secretary of Labor retains final coverage authority under Reorganization Plan Number 14.

29. RECOVERY ACT TRANSACTIONS LISTED IN SCHEDULE OF EXPENDITURES OF FEDERAL AWARDS AND RECIPIENT RESPONSIBILITIES FOR INFORMING SUBRECIPIENTS (MAY 2009)

- a. To maximize the transparency and accountability of funds authorized under the American Recovery and Reinvestment Act of 2009 (Pub. L. 111--5) (Recovery Act) as required by Congress and in accordance with 2 CFR 215.21 "Uniform Administrative Requirements for Grants and Agreements" and OMB Circular A--102 Common Rules provisions, recipients agree to maintain records that identify adequately the source and application of Recovery Act funds. OMB Circular A--102 is available at <http://www.whitehouse.gov/omb/circulars/a102/a102.html>
- b. For recipients covered by the Single Audit Act Amendments of 1996 and OMB Circular A--133, "Audits of States, Local Governments, and Non-Profit Organizations," recipients agree to separately identify the expenditures for Federal awards under the Recovery Act on the Schedule of Expenditures of Federal Awards (SEFA) and the Data Collection Form (SF--SAC) required by OMB Circular A--133. OMB Circular A--133 is available at <http://www.whitehouse.gov/omb/circulars/a133/a133.html>. This shall be accomplished by identifying expenditures for Federal awards made under the Recovery Act separately on the SEFA, and as separate rows under Item 9 of Part III on the SF--SAC by CFDA number, and inclusion of the prefix "ARRA-" in identifying the name of the Federal program on the SEFA and as the first characters in Item 9d of Part III on the SF--SAC.
- c. Recipients agree to separately identify to each subrecipient, and document at the time of subaward and at the time of disbursement of funds, the Federal award number, CFDA number, and amount of Recovery Act funds. When a recipient awards Recovery Act funds for an existing program, the information furnished to subrecipients shall distinguish the subawards of incremental Recovery Act funds from regular subawards under the existing program.
- d. Recipients agree to require their subrecipients to include on their SEFA information to specifically identify Recovery Act funding similar to the requirements for the recipient SEFA described above. This information is needed to allow the recipient to properly monitor subrecipient expenditure of ARRA funds as well as oversight by the Federal awarding agencies, Offices of Inspector General and

the Government Accountability Office.

30. **DAVIS BACON ACT REQUIREMENTS (MAY 2009)**

THIS AWARD TERM IS APPLICABLE TO ARRA AWARDS WHEN WAGE RATE REQUIREMENTS UNDER SECTION 1606 OF THE RECOVERY ACT TERM IS APPLICABLE. THIS AWARD TERM IS ALSO APPLICABLE TO SUBGRANTS AND CONTRACTS.

Note: Where necessary to make the context of these articles applicable to this award, the term "Contractor" shall mean "Recipient" and the term "Subcontractor" shall mean "Subrecipient or Subcontractor" per the following definitions.

Recipient means the organization, individual, or other entity that receives an award from DOE and is financially accountable for the use of any DOE funds or property provided for the performance of the project, and is legally responsible for carrying out the terms and conditions of the award.

Subrecipient means the legal entity to which a subaward is made and which is accountable to the recipient for the use of the funds provided. The term may include foreign or international organizations (such as agencies of the United Nations).

Davis-Bacon Act

(a) *Definition.*—"Site of the work"—

(1) Means--

- (i) The primary site of the work. The physical place or places where the construction called for in the award will remain when work on it is completed; and
- (ii) The secondary site of the work, if any. Any other site where a significant portion of the building or work is constructed, provided that such site is—
 - (A) Located in the United States; and
 - (B) Established specifically for the performance of the award or project;

(2) Except as provided in paragraph (3) of this definition, includes any fabrication plants, mobile factories, batch plants, borrow pits, job headquarters, tool yards, etc., provided—

- (i) They are dedicated exclusively, or nearly so, to performance of the award or project; and
- (ii) They are adjacent or virtually adjacent to the "primary site of the work" as defined in paragraph (a)(1)(i), or the "secondary site of the work" as defined in paragraph (a)(1)(ii) of this definition;

(3) Does not include permanent home offices, branch plant establishments, fabrication plants, or tool yards of a Contractor or subcontractor whose locations and continuance in operation are determined wholly without regard to a particular Federal award or project. In addition, fabrication plants, batch plants, borrow pits, job headquarters, yards, etc., of a commercial or material supplier which are established by a supplier of materials for the project before opening of bids and not on the Project site, are not included in the "site of the work." Such permanent, previously established facilities are not a part of the "site of the work" even if the operations for a period of time may be dedicated exclusively or nearly so, to the performance of an award.

(b) (1) All laborers and mechanics employed or working upon the site of the work will be paid unconditionally and not less often than once a week, and without subsequent deduction or rebate on any account (except such payroll deductions as are permitted by regulations issued by the Secretary of Labor under the Copeland Act (29 CFR Part 3)), the full amount of wages and bona fide fringe benefits (or cash equivalents thereof) due at time of payment computed at rates not less than those contained in the wage determination of the Secretary of Labor which is attached hereto and made a part hereof, or as may be incorporated for a secondary site of the work, regardless of any contractual relationship which may be alleged to exist between the Contractor and such

laborers and mechanics. Any wage determination incorporated for a secondary site of the work shall be effective from the first day on which work under the award was performed at that site and shall be incorporated without any adjustment in award price or estimated cost. Laborers employed by the construction Contractor or construction subcontractor that are transporting portions of the building or work between the secondary site of the work and the primary site of the work shall be paid in accordance with the wage determination applicable to the primary site of the work.

- (2) Contributions made or costs reasonably anticipated for bona fide fringe benefits under section 1(b)(2) of the Davis-Bacon Act on behalf of laborers or mechanics are considered wages paid to such laborers or mechanics, subject to the provisions of paragraph (e) of this article; also, regular contributions made or costs incurred for more than a weekly period (but not less often than quarterly) under plans, funds, or programs which cover the particular weekly period, are deemed to be constructively made or incurred during such period.
 - (3) Such laborers and mechanics shall be paid not less than the appropriate wage rate and fringe benefits in the wage determination for the classification of work actually performed, without regard to skill, except as provided in the article entitled Apprentices and Trainees. Laborers or mechanics performing work in more than one classification may be compensated at the rate specified for each classification for the time actually worked therein; provided, that the employer's payroll records accurately set forth the time spent in each classification in which work is performed.
 - (4) The wage determination (including any additional classifications and wage rates conformed under paragraph (c) of this article) and the Davis-Bacon poster (WH-1321) shall be posted at all times by the Contractor and its subcontractors at the site of the work in a prominent and accessible place where it can be easily seen by the workers.
- c. (1) The Contracting Officer shall require that any class of laborers or mechanics which is not listed in the wage determination and which is to be employed under the award shall be classified in conformance with the wage determination. The Contracting Officer shall approve an additional classification and wage rate and fringe benefits therefore only when all the following criteria have been met:
- (i) The work to be performed by the classification requested is not performed by a classification in the wage determination.
 - (ii) The classification is utilized in the area by the construction industry.
 - (iii) The proposed wage rate, including any bona fide fringe benefits, bears a reasonable relationship to the wage rates contained in the wage determination.
- (2) If the Contractor and the laborers and mechanics to be employed in the classification (if known), or their representatives and the Contracting Officer agree on the classification and wage rate (including the amount designated for fringe benefits, where appropriate), a report of the action taken shall be sent by the Contracting Officer to the Administrator of the:

Wage and Hour Division
Employment Standards Administration
U.S. Department of Labor
Washington, DC 20210

The Administrator or an authorized representative will approve, modify, or disapprove every additional classification action within 30 days of receipt and so advise the Contracting Officer or will notify the Contracting Officer within the 30-day period that additional time is necessary.

- (3) In the event the Contractor, the laborers or mechanics to be employed in the classification, or their representatives, and the Contracting Officer do not agree on the proposed classification and wage rate (including the amount designated for fringe benefits, where appropriate), the Contracting Officer shall refer the questions, including the views of all interested parties and the

recommendation of the Contracting Officer, to the Administrator of the Wage and Hour Division for determination. The Administrator, or an authorized representative, will issue a determination within 30 days of receipt and so advise the Contracting Officer or will notify the Contracting Officer within the 30-day period that additional time is necessary.

- (4) The wage rate (including fringe benefits, where appropriate) determined pursuant to subparagraphs (c)(2) and (c)(3) of this article shall be paid to all workers performing work in the classification under this award from the first day on which work is performed in the classification.
- (d) Whenever the minimum wage rate prescribed in the award for a class of laborers or mechanics includes a fringe benefit which is not expressed as an hourly rate, the Contractor shall either pay the benefit as stated in the wage determination or shall pay another bona fide fringe benefit or an hourly cash equivalent thereof.
- (e) If the Contractor does not make payments to a trustee or other third person, the Contractor may consider as part of the wages of any laborer or mechanic the amount of any costs reasonably anticipated in providing bona fide fringe benefits under a plan or program; provided, that the Secretary of Labor has found, upon the written request of the Contractor, that the applicable standards of the Davis-Bacon Act have been met. The Secretary of Labor may require the Contractor to set aside in a separate account assets for the meeting of obligations under the plan or program.

Rates of Wages

The minimum wages to be paid laborers and mechanics under this award involved in performance of work at the project site, as determined by the Secretary of Labor to be prevailing for the corresponding classes of laborers and mechanics employed on projects of a character similar to the contract work in the pertinent locality, are included as an attachment to this award. These wage rates are minimum rates and are not intended to represent the actual wage rates that the Contractor may have to pay.

Payrolls and Basic Records

- (a) Payrolls and basic records relating thereto shall be maintained by the Contractor during the course of the work and preserved for a period of 3 years thereafter for all laborers and mechanics working at the site of the work. Such records shall contain the name, address, and social security number of each such worker, his or her correct classification, hourly rates of wages paid (including rates of contributions or costs anticipated for bona fide fringe benefits or cash equivalents thereof of the types described in section 1(b)(2)(B) of the Davis-Bacon Act), daily and weekly number of hours worked, deductions made, and actual wages paid. Whenever the Secretary of Labor has found, under paragraph (d) of the article entitled Davis-Bacon Act, that the wages of any laborer or mechanic include the amount of any costs reasonably anticipated in providing benefits under a plan or program described in section 1(b)(2)(B) of the Davis-Bacon Act, the Contractor shall maintain records which show that the commitment to provide such benefits is enforceable, that the plan or program is financially responsible, and that the plan or program has been communicated in writing to the laborers or mechanics affected, and records which show the costs anticipated or the actual cost incurred in providing such benefits. Contractors employing apprentices or trainees under approved programs shall maintain written evidence of the registration of apprenticeship programs and certification of trainee programs, the registration of the apprentices and trainees, and the ratios and wage rates prescribed in the applicable programs.
- (b) (1) The Contractor shall submit weekly for each week in which any award work is performed a copy of all payrolls to the Contracting Officer. The payrolls submitted shall set out accurately and completely all of the information required to be maintained under paragraph (a) of this article, except that full social security numbers and home addresses shall not be included on weekly transmittals. Instead the payrolls shall only need to include an individually identifying number for each employee (e.g., the last four digits of the employee's social security number). This information may be submitted in any form desired. Optional Form WH-347 (Federal Stock Number 029-005-00014-1) is available for this purpose and may be purchased from the --

Superintendent of Documents U.S. Government Printing Office Washington, DC 20402

The Prime Contractor is responsible for the submission of copies of payrolls by all subcontractors. Contractors and subcontractors shall maintain the full social security number and current address of each covered worker, and shall provide them upon request to the Contracting Officer if the agency is a party to the contract, but if the agency is not such a party, the contractor will submit them to the applicant, sponsor, or owner, as the case may be for transmission to the Contracting Officer, the contractor, or the Wage and House Division of the Department of Labor for purposes of an investigation or audit of compliance with prevailing wage requirements. It is not a violation of this section for a prime contractor to require a subcontractor to provide addresses and social security numbers to the prime contractor for its own records, without weekly submission to the sponsoring government agency (or the applicant, sponsor, or owner).

- (2) Each payroll submitted shall be accompanied by a "Statement of Compliance," signed by the Contractor or subcontractor or his or her agent who pays or supervises the payment of the persons employed under the award and shall certify --
 - (i) That the payroll for the payroll period contains the information required to be provided under paragraph (b)(1) of this article, the appropriate information is being maintained under paragraph (a) of this article and that such information is correct and complete;
 - (ii) That each laborer or mechanic (including each helper, apprentice, and trainee) employed on the award during the payroll period has been paid the full weekly wages earned, without rebate, either directly or indirectly, and that no deductions have been made either directly or indirectly from the full wages earned, other than permissible deductions as set forth in the Regulations, 29 CFR Part 3; and
 - (iii) That each laborer or mechanic has been paid not less than the applicable wage rates and fringe benefits or cash equivalents for the classification of work performed, as specified in the applicable wage determination incorporated into the award.
 - (3) The weekly submission of a properly executed certification set forth on the reverse side of Optional Form WH-347 shall satisfy the requirement for submission of the "Statement of Compliance" required by subparagraph (b)(2) of this article.
 - (4) The falsification of any of the certifications in this article may subject the Contractor or subcontractor to civil or criminal prosecution under Section 1001 of Title 18 and Section 3729 of Title 31 of the United States Code.
- (c) The Contractor or subcontractor shall make the records required under paragraph (a) of this article available for inspection, copying, or transcription by the Contracting Officer or authorized representatives of the Contracting Officer or the Department of Labor. The Contractor or subcontractor shall permit the Contracting Officer or representatives of the Contracting Officer or the Department of Labor to interview employees during working hours on the job. If the Contractor or subcontractor fails to submit required records or to make them available, the Contracting Officer may, after written notice to the Contractor, take such action as may be necessary to cause the suspension of any further payment. Furthermore, failure to submit the required records upon request or to make such records available may be grounds for debarment action pursuant to 29 CFR 5.12.

Withholding of Funds

The Contracting Officer shall, upon his or her own action or upon written request of an authorized representative of the Department of Labor, withhold or cause to be withheld from the Contractor under this award or any other Federal award with the same Prime Contractor, or any other federally assisted award subject to Davis-Bacon prevailing wage requirements, which is held by the same Prime Contractor, so much of the accrued payments or advances as may be considered necessary to pay laborers and mechanics, including apprentices, trainees, and helpers, employed by the Contractor or any subcontractor the full amount of wages required by the award. In the event of failure to pay any laborer or mechanic, including any apprentice, trainee, or helper, employed or working on the site of the work, all or part of the wages

required by the award, the Contracting Officer may, after written notice to the Contractor, take such action as may be necessary to cause the suspension of any further payment, advance, or guarantee of funds until such violations have ceased.

Apprentices and Trainees

(a) Apprentices.

- (1) An apprentice will be permitted to work at less than the predetermined rate for the work they performed when they are employed—
 - (i) Pursuant to and individually registered in a bona fide apprenticeship program registered with the U.S. Department of Labor, Employment and Training Administration, Office of Apprenticeship and Training, Employer, and Labor Services (OATELS) or with a State Apprenticeship Agency recognized by the OATELS; or
 - (ii) In the first 90 days of probationary employment as an apprentice in such an apprenticeship program, even though not individually registered in the program, if certified by the OATELS or a State Apprenticeship Agency (where appropriate) to be eligible for probationary employment as an apprentice.
- (2) The allowable ratio of apprentices to journeymen on the job site in any craft classification shall not be greater than the ratio permitted to the Contractor as to the entire work force under the registered program.
- (3) Any worker listed on a payroll at an apprentice wage rate, who is not registered or otherwise employed as stated in paragraph (a)(1) of this article, shall be paid not less than the applicable wage determination for the classification of work actually performed. In addition, any apprentice performing work on the job site in excess of the ratio permitted under the registered program shall be paid not less than the applicable wage rate on the wage determination for the work actually performed.
- (4) Where a contractor is performing construction on a project in a locality other than that in which its program is registered, the ratios and wage rates (expressed in percentages of the journeyman's hourly rate) specified in the Contractor's or subcontractor's registered program shall be observed. Every apprentice must be paid at not less than the rate specified in the registered program for the apprentice's level of progress, expressed as a percentage of the journeyman hourly rate specified in the applicable wage determination.
- (5) Apprentices shall be paid fringe benefits in accordance with the provisions of the apprenticeship program. If the apprenticeship program does not specify fringe benefits, apprentices must be paid the full amount of fringe benefits listed on the wage determination for the applicable classification. If the Administrator determines that a different practice prevails for the applicable apprentice classification, fringes shall be paid in accordance with that determination.
- (6) In the event OATELS, or a State Apprenticeship Agency recognized by OATELS, withdraws approval of an apprenticeship program, the Contractor will no longer be permitted to utilize apprentices at less than the applicable predetermined rate for the work performed until an acceptable program is approved.

(b) Trainees.

- (1) Except as provided in 29 CFR 5.16, trainees will not be permitted to work at less than the predetermined rate for the work performed unless they are employed pursuant to and individually registered in a program which has received prior approval, evidenced by formal certification by the U.S. Department of Labor, Employment and Training Administration, Office of Apprenticeship Training, Employer, and Labor Services (OATELS). The ratio of trainees to journeymen on the job site shall not be greater than permitted under the plan approved by

OATELS.

- (2) Every trainee must be paid at not less than the rate specified in the approved program for the trainee's level of progress, expressed as a percentage of the journeyman hourly rate specified in the applicable wage determination. Trainees shall be paid fringe benefits in accordance with the provisions of the trainee program. If the trainee program does not mention fringe benefits, trainees shall be paid the full amount of fringe benefits listed in the wage determination unless the Administrator of the Wage and Hour Division determines that there is an apprenticeship program associated with the corresponding journeyman wage rate in the wage determination which provides for less than full fringe benefits for apprentices. Any employee listed on the payroll at a trainee rate who is not registered and participating in a training plan approved by the OATELS shall be paid not less than the applicable wage rate in the wage determination for the classification of work actually performed. In addition, any trainee performing work on the job site in excess of the ratio permitted under the registered program shall be paid not less than the applicable wage rate in the wage determination for the work actually performed.
- (3) In the event OATELS withdraws approval of a training program, the Contractor will no longer be permitted to utilize trainees at less than the applicable predetermined rate for the work performed until an acceptable program is approved.
- (d) Equal employment opportunity. The utilization of apprentices, trainees, and journeymen under this article shall be in conformity with the equal employment opportunity requirements of Executive Order 11246, as amended, and 29 CFR Part 30.

Compliance with Copeland Act Requirements

The Contractor shall comply with the requirements of 29 CFR Part 3, which are hereby incorporated by reference in this award.

Subcontracts (Labor Standards)

- (a) Definition. "Construction, alteration or repair," as used in this article means all types of work done by laborers and mechanics employed by the construction Contractor or construction subcontractor on a particular building or work at the site thereof, including without limitation—
 - (1) Altering, remodeling, installation (if appropriate) on the site of the work of items fabricated off-site;
 - (2) Painting and decorating;
 - (3) Manufacturing or furnishing of materials, articles, supplies, or equipment on the site of the building or work;
 - (4) Transportation of materials and supplies between the site of the work within the meaning of paragraphs (a)(1)(i) and (ii) of the "site of the work" as defined in the article entitled Davis Bacon Act of this award, and a facility which is dedicated to the construction of the building or work and is deemed part of the site of the work within the meaning of paragraph (2) of the "site of work" definition; and
 - (5) Transportation of portions of the building or work between a secondary site where a significant portion of the building or work is constructed, which is part of the "site of the work" definition in paragraph (a)(1)(ii) of the Davis-Bacon Act article, and the physical place or places where the building or work will remain (paragraph (a)(1)(i) of the Davis Bacon Act article, in the "site of the work" definition).
- (b) The Contractor or subcontractor shall insert in any subcontracts for construction, alterations and repairs

within the United States the articles entitled---

- (1) Davis-Bacon Act;
 - (2) Contract Work Hours and Safety Standards Act -- Overtime Compensation (if the article is included in this award);
 - (3) Apprentices and Trainees;
 - (4) Payrolls and Basic Records;
 - (5) Compliance with Copeland Act Requirements;
 - (6) Withholding of Funds;
 - (7) Subcontracts (Labor Standards);
 - (8) Contract Termination -- Debarment;
 - (9) Disputes Concerning Labor Standards;
 - (10) Compliance with Davis-Bacon and Related Act Regulations; and
 - (11) Certification of Eligibility.
- (c) The Prime Contractor shall be responsible for compliance by any subcontractor or lower tier subcontractor performing construction within the United States with all the award articles cited in paragraph (b).
- (d) (1) Within 14 days after issuance of the award, the Contractor shall deliver to the Contracting Officer a completed Standard Form (SF) 1413, Statement and Acknowledgment, for each subcontract for construction within the United States, including the subcontractor's signed and dated acknowledgment that the articles set forth in paragraph (b) of this article have been included in the subcontract.
- Within 14 days after the award of any subsequently awarded subcontract the Contractor shall deliver to the Contracting Officer an updated completed SF 1413 for such additional subcontract.
- (e) The Contractor shall insert the substance of this article, including this paragraph (e) in all subcontracts for construction within the United States.

Contract Termination -- Debarment

A breach of the award articles entitled Davis-Bacon Act, Contract Work Hours and Safety Standards Act -- Overtime Compensation, Apprentices and Trainees, Payrolls and Basic Records, Compliance with Copeland Act Requirements, Subcontracts (Labor Standards), Compliance with Davis-Bacon and Related Act Regulations, or Certification of Eligibility may be grounds for termination of the whole award or in part for the Recovery Act covered work only, and for debarment as a Contractor and subcontractor as provided in 29 CFR 5.12.

Compliance with Davis-Bacon and Related Act Regulations

All rulings and interpretations of the Davis-Bacon and Related Acts contained in 29 CFR Parts 1, 3, and 5 are hereby incorporated by reference in this award.

Disputes Concerning Labor Standards

The United States Department of Labor has set forth in 29 CFR Parts 5, 6, and 7 procedures for resolving disputes concerning labor standards requirements. Such disputes shall be resolved in accordance with those procedures and not the Disputes and Appeals as defined in 10 CFR 600.22. Disputes within the meaning of this article include disputes between the Contractor (or any of its subcontractors) and the contracting agency, the U.S. Department of Labor, or the employees or their representatives.

Certification of Eligibility

- (a) By entering into this award, the Contractor certifies that neither it (nor he or she) nor any person or firm who has an interest in the Contractor's firm is a person or firm ineligible to be awarded Government awards by virtue of section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1).
- (b) No part of this award shall be subcontracted to any person or firm ineligible for award of a Government award by virtue of section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1).
- (c) The penalty for making false statements is prescribed in the U.S. Criminal Code, 18 U.S.C. 1001.

Approval of Wage Rates

All straight time wage rates, and overtime rates based thereon, for laborers and mechanics engaged in work under this award must be submitted for approval in writing by the head of the contracting activity or a representative expressly designated for this purpose, if the straight time wages exceed the rates for corresponding classifications contained in the applicable Davis-Bacon Act minimum wage determination included in the award. Any amount paid by the Contractor to any laborer or mechanic in excess of the agency approved wage rate shall be at the expense of the Contractor and shall not be reimbursed by the Government. If the Government refuses to authorize the use of the overtime, the Contractor is not released from the obligation to pay employees at the required overtime rates for any overtime actually worked.

31. HISTORIC PRESERVATION

Prior to the expenditure of Federal funds to alter any structure or site, the Recipient is required to comply with the requirements of Section 106 of the National Historic Preservation Act (NHPA), consistent with DOE's 2009 letter of delegation of authority regarding the NHPA. Section 106 applies to historic properties that are listed in or eligible for listing in the National Register of Historic Places. In order to fulfill the requirements of Section 106, the Recipient must contact the State Historic Preservation Officer (SHPO), and, if applicable, the Tribal Historic Preservation Officer (THPO), to coordinate the Section 106 review outlined in 36 CFR Part 800. SHPO contact information is available at the following link: <http://www.ncshpo.org/find/index.htm>. THPO contact information is available at the following link: <http://www.nathpo.org/map.html>.

Section 110(k) of the NHPA applies to DOE funded activities. Recipients shall avoid taking any action that results in an adverse effect to historic properties pending compliance with Section 106.

Recipients should be aware that the DOE Contracting Officer will consider compliance with Section 106 of NHPA complete only after the Recipient has submitted adequate background documentation to the SHPO/THPO for its review, and the SHPO/THPO has provided written concurrence to the Recipient that it does not object to its Section 106 finding or determination. Recipient shall provide a copy of this concurrence to the Contracting Officer.

ATTACHMENT 1 – INTELLECTUAL PROPERTY PROVISIONS

**Intellectual Property Provisions (NRD-1003)
Nonresearch and Development**

Nonprofit organizations are subject to the intellectual property requirements at 10 CFR 600.136(a), (c) and (d). All other organizations are subject to the intellectual property requirements at 10 CFR 600.136(a) and (c).

600.136 Intangible property.

(a) Recipients may copyright any work that is subject to copyright and was developed, or for which ownership was purchased, under an award. DOE reserves a royalty-free, nonexclusive and irrevocable right to reproduce, publish or otherwise use the work for Federal purposes, and to authorize others to do so.

(c) DOE has the right to:


- (1) Obtain, reproduce, publish or otherwise use the data first produced under an award; and
- (2) Authorize others to receive, reproduce, publish, or otherwise use such data for Federal purposes.

(d) In addition, in response to a Freedom of Information act (FOIA) request for research data relating to published research findings produced under an award that were used by the Federal Government in developing an agency action that has the force and effect of law, the DOE shall request, and the recipient shall provide, within a reasonable time, the research data so that they can be made available to the public through the procedures established under the FOIA. If the DOE obtains the research data solely in response to a FOIA request, the agency may charge the requester a reasonable fee equaling the full incremental cost of obtaining the research data. This fee should reflect the costs incurred by the agency, the recipient, and applicable subrecipients. This fee is in addition to any fees the agency may assess under the FOIA (5 U.S.C. 552(a)(4)(A)).

Exhibit "C"

[FIRE STATION 118 PLANS]

2700 WEST STREET



- LEGEND**
- FINISH CONTOUR ELEVATION
 - FINISH CONTOUR ELEVATION
 - FINISH SPOT ELEVATION
 - FINISH SPOT ELEVATION
 - TOP OF ASPHALT
 - TOP OF CONCRETE
 - TOP BACK OF CURB
 - TOP OF SIDEWALK
 - FLOORLINE
 - DRAINAGE DIRECTION
 - PROPERTY LINE
 - EXISTING UTILITY LINE
 - NEW UTILITY LINE


- GENERAL NOTES:**
1. CONTRACTOR SHALL VERIFY ALL EXISTING AND NEW LOCATIONS AND DEPTHS BEFORE STARTING CONSTRUCTION.
 2. CONTRACTOR SHALL VERIFY LOCATION OF ALL EXISTING UTILITIES BEFORE STARTING CONSTRUCTION.
 3. CONTRACTOR SHALL FOLLOW PIPE MANUFACTURERS SPECIFICATIONS FOR THE INSTALLATION OF ALL PIPES.
 4. SLOPE LAYOUTS AT DOORWAYS ARE PER FOOT.
 5. SLOPE WORK AND UTILITIES SHALL CONFORM TO STANDARD DRAININGS AND SPECIFICATIONS.
 6. SEE SHEET A-1 FOR LOCATION OF STORM DRAIN CONDUITS.

Drainage Calculations

Area	Flow Rate (cfs)	Flow Rate (gpm)
Roof Area	1.000	4.483
Impervious Area	1.000	4.483
Permeable Area	0.000	0.000
TOTAL AREA	2.000	8.966

DESIGN FLOW FACTOR (U) = 0.51
a.s.c. on area

- APRIL 16, 1999 ADDED ADDENDUM NO. 2 SHEET C-1 ITEMS
- APRIL 24, 1999 REVISED DETENTION POND AND ADDED INLET BOX PER CITY ENGINEER REQUIREMENTS
- MAY 12, 1999 LOWERED BUILDING ELEVATION

















TAYLORSVILLE FIRE STATION
5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH

DRAWN BY
BILL GOULD
CHECKED BY
G.A.
JOB NO.
204
DATE
MARCH 30, 1999

PASKER GOULD AMES & WEAVER.
ARCHITECTS PLANNERS
5263 SOUTH 300 WEST
MURRAY, UTAH (801) 266-4669





TRASH ENCLOSURE DETAIL	SCALE: NONE	13	SCALE: NONE	14	SCALE: NONE	15
------------------------	-------------	----	-------------	----	-------------	----


ASPHALT PAVING SECTION	SCALE: NONE	4	TYPICAL CONCRETE JOINTS	SCALE: NONE	10	CONCRETE PAVING SECTION	SCALE: NONE	11	ORIFICE PLATE DETAIL	SCALE: NONE	12
------------------------	-------------	---	-------------------------	-------------	----	-------------------------	-------------	----	----------------------	-------------	----



SYMBOL DETAIL	SCALE: NONE	5	HANDICAP SIGN DETAIL	SCALE: NONE	6	HANDICAP RAMP CURB CUT DETAIL	SCALE: NONE	7	INLET BOX DETAIL	SCALE: NONE	8
---------------	-------------	---	----------------------	-------------	---	-------------------------------	-------------	---	------------------	-------------	---

SITE DETAILS
TAYLORSVILLE FIRE STATION
 5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH

DRAWN BY
 BILL GOULD
 CHECKED BY
 CLA
 JOB NO.
 204
 DATE
 MARCH 30, 1999

PASKER GOULD AMES & WEAVER
 ARCHITECTS PLANNERS
 5263 SOUTH 300 WEST
 MURRAY, UTAH (801) 266-4669





McNEIL ENGINEERING AND LAND SURVEYING, L.C.
 PROFESSIONAL CIVIL ENGINEERING & LAND SURVEYING SERVICES
 6535 SOUTH 830 EAST, MURKIN, UTAH 84047
 TEL: (801) 265-7100 FAX: (801) 725-5071 URL: www.mcneil.com

THE CITY OF TAYLORSVILLE
 2700 WEST 8 APPROX 5400 SOUTH
 LOCATION MAP & SURVEY OF 2700 WEST 8


STREET PLAN AND PROFILE DESIGN


DRAWING INFORMATION

REVISIONS	DATE	BY	CHKD BY
1	01/27/11	DM	DM
2	02/01/11	DM	DM
3	02/01/11	DM	DM
4	02/01/11	DM	DM
5	02/01/11	DM	DM
6	02/01/11	DM	DM
7	02/01/11	DM	DM
8	02/01/11	DM	DM
9	02/01/11	DM	DM
10	02/01/11	DM	DM


JOB NO. 191990

SHEET NUMBER C-3






NOTE: PLANT TREE AT SAME RELATIONSHIP TO BUILDING AS SHOWN IN THIS SECTION. TREE SHOULD BE PLANTED WITHIN 10' OF BUILDING.




NOTE: PLANT TREE AT SAME RELATIONSHIP TO BUILDING AS SHOWN IN THIS SECTION. TREE SHOULD BE PLANTED WITHIN 10' OF BUILDING.



CONCRETE HOW CURBS
SCALE: NONE

- NOTES:
1. CONSTRUCTION SHALL ASSURE POSITIVE DRAINAGE AWAY FROM THE BUILDING AND ALL AREAS OF THE LANDSCAPE.
 2. NOT TO BE CONSIDERED A CONTRACT DOCUMENT UNLESS APPROVED BY THE ARCHITECT.
 3. ALL SHEDS SHALL BE CONSTRUCTED WITH 1" OF FALL FOR DRAINAGE.
 4. ALL SHEDS SHALL BE CONSTRUCTED WITH 1" OF FALL FOR DRAINAGE.
 5. ALL TREES TO BE PLANTED ON CORNER IMPROVEMENT YARDS.
 6. ALL LAND AREAS SHALL BE GRASSED WITH PERENNIAL BLENDED GRASS.
 7. PLANTING SHALL BE PERFORMED BY THE LANDSCAPE CONTRACTOR UNLESS OTHERWISE NOTED.
 8. LAND AREAS SHALL BE FERTILIZED BEFORE PLANTING AND SHALL BE MAINTAINED THROUGHOUT THE LIFE OF THE PROJECT.
 9. ALL LANDS AND PLANTING AREAS SHALL BE SEPARATED BY A 4" VOR CONCRETE POUR STRIP.
 10. ALL SHEDS SHALL BE CONSTRUCTED WITH 1" OF FALL FOR DRAINAGE.
 11. ALL SHEDS SHALL BE CONSTRUCTED WITH 1" OF FALL FOR DRAINAGE.
 12. ALL SHEDS SHALL BE CONSTRUCTED WITH 1" OF FALL FOR DRAINAGE.
 13. ALL SHEDS SHALL BE CONSTRUCTED WITH 1" OF FALL FOR DRAINAGE.
 14. ALL SHEDS SHALL BE CONSTRUCTED WITH 1" OF FALL FOR DRAINAGE.



PLANT SCHEDULE


KEY	BOTANICAL NAME	COMMON NAME	SIZE	REMARKS	PLANTING QUANTITY
1	FRAXINUS AMERICANA	RED BARK OAK	12\"/>		
2	QUERCUS ALBA	WHITE OAK	12\"/>		
3	QUERCUS PRINCEPIUM	PRINCIPAL OAK	12\"/>		
4	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
5	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
6	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
7	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
8	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
9	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
10	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
11	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
12	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
13	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
14	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
15	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
16	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
17	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
18	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
19	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
20	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
21	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
22	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
23	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
24	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
25	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
26	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
27	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
28	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
29	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
30	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
31	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
32	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
33	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
34	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
35	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
36	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
37	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
38	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
39	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
40	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
41	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
42	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
43	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
44	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
45	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
46	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
47	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
48	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
49	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		
50	QUERCUS LAEVIS	SMOOTH LEAF OAK	12\"/>		

LANDSCAPE PLAN




LANDSCAPE ARCHITECT: GREG HOLLEY

	<p>LANDSCAPE PLAN</p> <p>TAYLORSVILLE FIRE STATION</p> <p>5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH</p>	<p>DRAWN BY: BILL GOLD</p> <p>CHECKED BY: G.A.</p> <p>JOB NO.: 204</p> <p>DATE: MARCH 20, 1994</p>	<p>PASKER GOULD AMES & WEAVER</p> <p>ARCHITECTS PLANNERS</p> <p>5263 SOUTH 300 WEST MURRAY, UTAH (801) 266-4669</p>
	<p>1</p>	<p>1</p>	<p>1</p>



BACKFLOW PREVENTOR
DETAIL VIEW



DRIP VALVE & BOX DETAIL
DETAIL VIEW

PIPE SIZES


1/2" Pvc Pipe	1/2"
3/4" Pvc Pipe	3/4"
1" Pvc Pipe	1"
1 1/2" Pvc Pipe	1 1/2"
2" Pvc Pipe	2"
3" Pvc Pipe	3"
4" Pvc Pipe	4"
6" Pvc Pipe	6"
8" Pvc Pipe	8"
10" Pvc Pipe	10"
12" Pvc Pipe	12"

SPRINKLER SYSTEM NOTES

1. NOTIFY INSURANCE AGENT IMMEDIATELY IF FIELD CONDITIONS DIFFER FROM ACTUAL. THE CONTRACTOR SHALL BE RESPONSIBLE FOR NOTIFYING THE AGENT.
2. NOTIFY THE SCHEDULER FOR ALL UNDERGROUND UTILITIES AND HAVE SITE MARKED FOR ALL UNDERGROUND UTILITIES.
3. PROTECT ALL UTILITIES. ALL UTILITIES SHALL BE EXCAVATED TO REVEAL THEIR DEPTHS AND LOCATIONS. EXCAVATED UTILITIES SHALL BE PROTECTED BY 18" MINIMUM CONCRETE SLABS.
4. ALL SPRINKLER PIPE AND UTILITY SHALL BE PLACED IN 4" CLASH TUBING. CONCRETE SHALL BE PLACED IN 4" CLASH TUBING. ALL SPRINKLER PIPE SHALL BE PLACED IN 4" CLASH TUBING. CONCRETE SHALL BE PLACED IN 4" CLASH TUBING. ALL SPRINKLER PIPE SHALL BE PLACED IN 4" CLASH TUBING. CONCRETE SHALL BE PLACED IN 4" CLASH TUBING.
5. PROTECT ALL UTILITIES. ALL UTILITIES SHALL BE EXCAVATED TO REVEAL THEIR DEPTHS AND LOCATIONS. EXCAVATED UTILITIES SHALL BE PROTECTED BY 18" MINIMUM CONCRETE SLABS.
6. BACKFLOW PREVENTOR TO BE NON-RECYCLED, NON-LUBRICATED MATERIAL. ALL BACKFLOW PREVENTORS SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL BACKFLOW PREVENTORS SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
7. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
8. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
9. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
10. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
11. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
12. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
13. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
14. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
15. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
16. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
17. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
18. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
19. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.
20. DRIP VALVE SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM. ALL DRIP VALVES SHALL BE INSTALLED IN THE MAIN LINE OF THE SYSTEM.


RAIN HEAD INSTALLATION DETAIL
DETAIL VIEW

2700 WEST STREET



SPRINKLER SCHEDULE

ITEM	DESCRIPTION	QUANTITY	UNIT
1	1/2" Pvc Pipe	100	LINEAL FEET
2	3/4" Pvc Pipe	50	LINEAL FEET
3	1" Pvc Pipe	20	LINEAL FEET
4	1 1/2" Pvc Pipe	10	LINEAL FEET
5	2" Pvc Pipe	5	LINEAL FEET
6	3" Pvc Pipe	2	LINEAL FEET
7	4" Pvc Pipe	1	LINEAL FEET
8	6" Pvc Pipe	1	LINEAL FEET
9	8" Pvc Pipe	1	LINEAL FEET
10	10" Pvc Pipe	1	LINEAL FEET
11	12" Pvc Pipe	1	LINEAL FEET
12	1/2" Pvc Elbow	100	PIECES
13	3/4" Pvc Elbow	50	PIECES
14	1" Pvc Elbow	20	PIECES
15	1 1/2" Pvc Elbow	10	PIECES
16	2" Pvc Elbow	5	PIECES
17	3" Pvc Elbow	2	PIECES
18	4" Pvc Elbow	1	PIECES
19	6" Pvc Elbow	1	PIECES
20	8" Pvc Elbow	1	PIECES
21	10" Pvc Elbow	1	PIECES
22	12" Pvc Elbow	1	PIECES
23	1/2" Pvc Tee	100	PIECES
24	3/4" Pvc Tee	50	PIECES
25	1" Pvc Tee	20	PIECES
26	1 1/2" Pvc Tee	10	PIECES
27	2" Pvc Tee	5	PIECES
28	3" Pvc Tee	2	PIECES
29	4" Pvc Tee	1	PIECES
30	6" Pvc Tee	1	PIECES
31	8" Pvc Tee	1	PIECES
32	10" Pvc Tee	1	PIECES
33	12" Pvc Tee	1	PIECES
34	1/2" Pvc Coupling	100	PIECES
35	3/4" Pvc Coupling	50	PIECES
36	1" Pvc Coupling	20	PIECES
37	1 1/2" Pvc Coupling	10	PIECES
38	2" Pvc Coupling	5	PIECES
39	3" Pvc Coupling	2	PIECES
40	4" Pvc Coupling	1	PIECES
41	6" Pvc Coupling	1	PIECES
42	8" Pvc Coupling	1	PIECES
43	10" Pvc Coupling	1	PIECES
44	12" Pvc Coupling	1	PIECES
45	1/2" Pvc Tee Tee	100	PIECES
46	3/4" Pvc Tee Tee	50	PIECES
47	1" Pvc Tee Tee	20	PIECES
48	1 1/2" Pvc Tee Tee	10	PIECES
49	2" Pvc Tee Tee	5	PIECES
50	3" Pvc Tee Tee	2	PIECES
51	4" Pvc Tee Tee	1	PIECES
52	6" Pvc Tee Tee	1	PIECES
53	8" Pvc Tee Tee	1	PIECES
54	10" Pvc Tee Tee	1	PIECES
55	12" Pvc Tee Tee	1	PIECES



SPRINKLER PLAN

LANDSCAPE ARCHITECT, GREG WOLFLEY




SPRINKLER PLAN
TAYLORSVILLE FIRE STATION
5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH


DRAWN BY
BILL GOLD
CHECKED BY
CLA
JOB NO.
204
DATE
MARCH 20, 1999

PASKER GOULD AMES & WEAVER
ARCHITECTS PLANNERS
5263 SOUTH 300 WEST
MURRAY, UTAH (801) 266-4669





FLOOR PLAN
Scale: 1/8" = 1'-0"




WALL TYPES
1-1/2" = 1'-0"
1

FLOOR PLAN
TAYLORSVILLE FIRE STATION
5521 SOUTH 2100 WEST TAYLORSVILLE, UTAH


DRAWN BY
BILL GOULD
CHECKED BY
CLA
JOB NO.
204
DATE
MARCH 30, 1968

PASKER GOULD AMES & WEAVER
ARCHITECTS PLANNERS
5263 SOUTH 300 WEST
MURRAY, UTAH (801) 266-4669






NORTH ELEVATION
SCALE: 1/8" = 1'-0"




EAST ELEVATION
SCALE: 1/8" = 1'-0"




SOUTH ELEVATION
SCALE: 1/8" = 1'-0"


WEST ELEVATION
SCALE: 1/8" = 1'-0"




PATIO WALL EAST ELEVATION
SCALE: 1/8" = 1'-0"




PATIO WALL SOUTH ELEVATION
SCALE: 1/8" = 1'-0"




TRASH ENCLOSURE NORTH ELEVATION
SCALE: 1/8" = 1'-0"




TYPICAL MASONRY PATTERN
SCALE: 1/2" = 1'-0"




1 BUILDING SECTION THROUGH SHERIFF & MEETING ROOM
SCALE: 1/4" = 1'-0"



2 BUILDING SECTION THROUGH LOBBY
SCALE: 1/4" = 1'-0"



3 BUILDING SECTION THROUGH APPARATUS BAY
SCALE: 1/4" = 1'-0"




BUILDING SECTIONS
TAYLORSVILLE FIRE STATION
 5521 SOUTH 2100 WEST TAYLORSVILLE, UTAH


DRAWN BY
 BILL GOULD
 CHECKED BY
 CLA
 JOB NO.
 2104
 DATE
 MARCH 30, 1994

PASKER GOULD AMES & WEAVER
 ARCHITECTS PLANNERS
 5263 SOUTH 300 WEST
 MURRAY, UTAH (801) 266-4669





1 BUILDING SECTION THROUGH HEATING ROOM @ DORMER
SCALE: 1/8"




2 BUILDING SECTION THROUGH KITCHEN & APPARATUS BAY
SCALE: 1/8"




BUILDING SECTIONS
TAYLORSVILLE FIRE STATION
 5321 SOUTH 2100 WEST TAYLORSVILLE, UTAH

DRAWN BY
 BILL GOLD
 CHECKED BY
 CLA
 JOB NO.
 304
 DATE
 MARCH 30, 1994

PASKER GOULD AMES & WEAVER
 ARCHITECTS PLANNERS
 5263 SOUTH 300 WEST MURRAY, UTAH (801) 266-4669





1 WALL SECTION
SCALE 3/4"=1'-0"

2 WALL SECTION
SCALE 3/4"=1'-0"

3 WALL SECTION
SCALE 3/4"=1'-0"

WALL SECTIONS


TAYLORSVILLE FIRE STATION




5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH

DRAWN BY
BELL GOULD
CHECKED BY
CLA
JOB NO.
206
DATE
MARCH 30, 1994

PASKER GOULD AMES & WEAVER
ARCHITECTS PLANNERS

5263 SOUTH 300 WEST MURRAY, UTAH (801) 266-4669





WALL SECTIONS

TAYLORSVILLE FIRE STATION

5321 SOUTH 2100 WEST TAYLORSVILLE, UTAH

DRAWN BY
BILL GOLD

CHECKED BY
CLA

JOB NO.
204

DATE
MARCH 20, 1994


PASKER GOULD AMES & WEAVER
ARCHITECTS PLANNERS

5263 SOUTH 300 WEST


MURRAY, UTAH (801) 266-4669




1 WALL SECTION AT OVERHANG / MOMENT FRAME
SCALE: 3/4"=1'-0"
APPENDIX DRAWINGS AD 3-1



2 WALL SECTION THROUGH SHOP AREA
SCALE: 3/4"=1'-0"







ENLARGED PLAN
SCALE: 1/4" = 1'-0"

TOILET AND BATH ACCESSORIES	
1	SOAP DISPENSER - LAVATORY MOUNTED
2	LIGHT TOILET PAPER DISPENSER
3	TOILET PAPER HOLDER
4	REFLECTOR
5	REFLECTOR - SEE ELEVATION FOR SIZE - SEE NOTE 1
6	REFLECTOR - SEE ELEVATION - ST. TERMINAL
7	SOAP DISPENSER - WALL MOUNTED
8	SHOWER MOUNTED SOAP DISPENSER
9	TOILET SEAT COVER DISPENSER
10	TOILET SEAT COVER DISPENSER
11	TOILET SEAT COVER DISPENSER
12	TOILET SEAT COVER DISPENSER
13	TOILET SEAT COVER DISPENSER
14	TOILET SEAT COVER DISPENSER
15	TOILET SEAT COVER DISPENSER
16	TOILET SEAT COVER DISPENSER


1. FOR TOILET SEAT COVER DISPENSER SEE SHEET 1-2
2. INSTALL ALL PROVIDED PIPES AT SIZES TYPICAL
3. FIELD TOILET PAPER DISPENSER



WOMEN 17 AND SHOWER 18 ELEVATIONS
SCALE: 1/4" = 1'-0"



MEN 15 AND SHOWER 16 ELEVATIONS
SCALE: 1/4" = 1'-0"



MEN 10 ELEVATIONS
SCALE: 1/4" = 1'-0"




WOMEN 09 ELEVATIONS
SCALE: 1/4" = 1'-0"

MULTI-PURPOSE 102 ELEVATION
SCALE: 1/4" = 1'-0"



TILE BASE DETAIL
SCALE: 1/4" = 1'-0"

















ENLARGED PLANS
TAYLORSVILLE FIRE STATION
5921 SOUTH 2100 WEST TAYLORSVILLE, UTAH

DRAWN BY
BILL GOLD
CHECKED BY
CLA
JOB NO.
304
DATE
MARCH 30, 1994

PASKER GOULD AMES & WEAVER
ARCHITECTS PLANNERS
5263 SOUTH 300 WEST
MURRAY, UTAH (801) 266-4669





PANTRY DETAIL	SCALE: 3/4" = 1'-0"	7	TYPICAL PARTITION HEAD DETAIL	SCALE: 3/4" = 1'-0"	11	SILL DETAIL	SCALE: 1-1/4" = 1'-0"	12	TYPICAL SILL DETAIL	SCALE: 3/4" = 1'-0"	13
---------------	---------------------	---	-------------------------------	---------------------	----	-------------	-----------------------	----	---------------------	---------------------	----



ENLARGED PLANS AND DETAILS

TAYLORSVILLE FIRE STATION

5921 SOUTH 2700 WEST TAYLORSVILLE, UTAH

DRAWN BY
BILL GOLD

CHECKED BY
CLA

JOB NO.
204

DATE
MARCH 30, 1991


PASKER GOULD AMES & WEAVER

ARCHITECTS PLANNERS


5263 SOUTH 300 WEST

MURRAY, UTAH (801) 266-4669







PASS-THRU BASE DET. SCALE: 1" = 1'-0" 1/4" SECTION THROUGH




ROLL-OUT BASE SCALE: 1" = 1'-0"




UPPER CABINET DET. SCALE: 1" = 1'-0" U-1 & U-2




GARBAGE BASE DET. SCALE: 1" = 1'-0"




SINK BASE CABINET SCALE: 1" = 1'-0"




3 DRAWER BASE DET. SCALE: 1" = 1'-0"




ROLL-OUT BASE DET. SCALE: 1" = 1'-0"




6 DRAWER BASE DET. SCALE: 1" = 1'-0"



DORM ROOM BASE DET. SCALE: 1" = 1'-0"



DIVIDED BASE DET. SCALE: 1" = 1'-0"




WARDROBE DET. SCALE: 1" = 1'-0"




PASKER GOULD AMES & WEAVER ARCHITECTS PLANNERS
5263 SOUTH 300 WEST MURRAY, UTAH (801) 266-4669

DRAWN BY BILL GOULD
CHECKED BY CLA
JOB NO. 204
DATE MARCH 30, 1994

MILLWORK SECTIONS
TAYLORSVILLE FIRE STATION
5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH




NO	WINDOW FRAME TYPE	FIGURE	Q-CLASS	HEAD	JAMB	SILL	REMARKS	NO
1	WOOD GLAZ	1	WOOD GLAZ	11A13	11A13	11A13		1
2	WOOD GLAZ	2	WOOD GLAZ	11A13	11A13	11A13		2
3	WOOD GLAZ	3	WOOD GLAZ	11A13	11A13	11A13		3
4	WOOD GLAZ	4	WOOD GLAZ	11A13	11A13	11A13		4
5	WOOD GLAZ	5	WOOD GLAZ	11A13	11A13	11A13		5
6	WOOD GLAZ	6	WOOD GLAZ	11A13	11A13	11A13		6
7	WOOD GLAZ	7	WOOD GLAZ	11A13	11A13	11A13		7
8	WOOD GLAZ	8	WOOD GLAZ	11A13	11A13	11A13		8
9	WOOD GLAZ	9	WOOD GLAZ	11A13	11A13	11A13		9
10	WOOD GLAZ	10	WOOD GLAZ	11A13	11A13	11A13		10
11	WOOD GLAZ	11	WOOD GLAZ	11A13	11A13	11A13		11
12	WOOD GLAZ	12	WOOD GLAZ	11A13	11A13	11A13		12
13	WOOD GLAZ	13	WOOD GLAZ	11A13	11A13	11A13		13
14	WOOD GLAZ	14	WOOD GLAZ	11A13	11A13	11A13		14
15	WOOD GLAZ	15	WOOD GLAZ	11A13	11A13	11A13		15
16	WOOD GLAZ	16	WOOD GLAZ	11A13	11A13	11A13		16
17	WOOD GLAZ	17	WOOD GLAZ	11A13	11A13	11A13		17
18	WOOD GLAZ	18	WOOD GLAZ	11A13	11A13	11A13		18
19	WOOD GLAZ	19	WOOD GLAZ	11A13	11A13	11A13		19
20	WOOD GLAZ	20	WOOD GLAZ	11A13	11A13	11A13		20
21	WOOD GLAZ	21	WOOD GLAZ	11A13	11A13	11A13		21
22	WOOD GLAZ	22	WOOD GLAZ	11A13	11A13	11A13		22
23	WOOD GLAZ	23	WOOD GLAZ	11A13	11A13	11A13		23
24	WOOD GLAZ	24	WOOD GLAZ	11A13	11A13	11A13		24
25	WOOD GLAZ	25	WOOD GLAZ	11A13	11A13	11A13		25
26	WOOD GLAZ	26	WOOD GLAZ	11A13	11A13	11A13		26
27	WOOD GLAZ	27	WOOD GLAZ	11A13	11A13	11A13		27
28	WOOD GLAZ	28	WOOD GLAZ	11A13	11A13	11A13		28
29	WOOD GLAZ	29	WOOD GLAZ	11A13	11A13	11A13		29
30	WOOD GLAZ	30	WOOD GLAZ	11A13	11A13	11A13		30
31	WOOD GLAZ	31	WOOD GLAZ	11A13	11A13	11A13		31
32	WOOD GLAZ	32	WOOD GLAZ	11A13	11A13	11A13		32
33	WOOD GLAZ	33	WOOD GLAZ	11A13	11A13	11A13		33
34	WOOD GLAZ	34	WOOD GLAZ	11A13	11A13	11A13		34
35	WOOD GLAZ	35	WOOD GLAZ	11A13	11A13	11A13		35
36	WOOD GLAZ	36	WOOD GLAZ	11A13	11A13	11A13		36
37	WOOD GLAZ	37	WOOD GLAZ	11A13	11A13	11A13		37
38	WOOD GLAZ	38	WOOD GLAZ	11A13	11A13	11A13		38
39	WOOD GLAZ	39	WOOD GLAZ	11A13	11A13	11A13		39
40	WOOD GLAZ	40	WOOD GLAZ	11A13	11A13	11A13		40
41	WOOD GLAZ	41	WOOD GLAZ	11A13	11A13	11A13		41
42	WOOD GLAZ	42	WOOD GLAZ	11A13	11A13	11A13		42
43	WOOD GLAZ	43	WOOD GLAZ	11A13	11A13	11A13		43
44	WOOD GLAZ	44	WOOD GLAZ	11A13	11A13	11A13		44
45	WOOD GLAZ	45	WOOD GLAZ	11A13	11A13	11A13		45
46	WOOD GLAZ	46	WOOD GLAZ	11A13	11A13	11A13		46
47	WOOD GLAZ	47	WOOD GLAZ	11A13	11A13	11A13		47
48	WOOD GLAZ	48	WOOD GLAZ	11A13	11A13	11A13		48
49	WOOD GLAZ	49	WOOD GLAZ	11A13	11A13	11A13		49
50	WOOD GLAZ	50	WOOD GLAZ	11A13	11A13	11A13		50
51	WOOD GLAZ	51	WOOD GLAZ	11A13	11A13	11A13		51
52	WOOD GLAZ	52	WOOD GLAZ	11A13	11A13	11A13		52
53	WOOD GLAZ	53	WOOD GLAZ	11A13	11A13	11A13		53
54	WOOD GLAZ	54	WOOD GLAZ	11A13	11A13	11A13		54
55	WOOD GLAZ	55	WOOD GLAZ	11A13	11A13	11A13		55
56	WOOD GLAZ	56	WOOD GLAZ	11A13	11A13	11A13		56
57	WOOD GLAZ	57	WOOD GLAZ	11A13	11A13	11A13		57
58	WOOD GLAZ	58	WOOD GLAZ	11A13	11A13	11A13		58
59	WOOD GLAZ	59	WOOD GLAZ	11A13	11A13	11A13		59
60	WOOD GLAZ	60	WOOD GLAZ	11A13	11A13	11A13		60
61	WOOD GLAZ	61	WOOD GLAZ	11A13	11A13	11A13		61
62	WOOD GLAZ	62	WOOD GLAZ	11A13	11A13	11A13		62
63	WOOD GLAZ	63	WOOD GLAZ	11A13	11A13	11A13		63
64	WOOD GLAZ	64	WOOD GLAZ	11A13	11A13	11A13		64
65	WOOD GLAZ	65	WOOD GLAZ	11A13	11A13	11A13		65
66	WOOD GLAZ	66	WOOD GLAZ	11A13	11A13	11A13		66
67	WOOD GLAZ	67	WOOD GLAZ	11A13	11A13	11A13		67
68	WOOD GLAZ	68	WOOD GLAZ	11A13	11A13	11A13		68
69	WOOD GLAZ	69	WOOD GLAZ	11A13	11A13	11A13		69
70	WOOD GLAZ	70	WOOD GLAZ	11A13	11A13	11A13		70
71	WOOD GLAZ	71	WOOD GLAZ	11A13	11A13	11A13		71
72	WOOD GLAZ	72	WOOD GLAZ	11A13	11A13	11A13		72
73	WOOD GLAZ	73	WOOD GLAZ	11A13	11A13	11A13		73
74	WOOD GLAZ	74	WOOD GLAZ	11A13	11A13	11A13		74
75	WOOD GLAZ	75	WOOD GLAZ	11A13	11A13	11A13		75
76	WOOD GLAZ	76	WOOD GLAZ	11A13	11A13	11A13		76
77	WOOD GLAZ	77	WOOD GLAZ	11A13	11A13	11A13		77
78	WOOD GLAZ	78	WOOD GLAZ	11A13	11A13	11A13		78
79	WOOD GLAZ	79	WOOD GLAZ	11A13	11A13	11A13		79
80	WOOD GLAZ	80	WOOD GLAZ	11A13	11A13	11A13		80
81	WOOD GLAZ	81	WOOD GLAZ	11A13	11A13	11A13		81
82	WOOD GLAZ	82	WOOD GLAZ	11A13	11A13	11A13		82
83	WOOD GLAZ	83	WOOD GLAZ	11A13	11A13	11A13		83
84	WOOD GLAZ	84	WOOD GLAZ	11A13	11A13	11A13		84
85	WOOD GLAZ	85	WOOD GLAZ	11A13	11A13	11A13		85
86	WOOD GLAZ	86	WOOD GLAZ	11A13	11A13	11A13		86
87	WOOD GLAZ	87	WOOD GLAZ	11A13	11A13	11A13		87
88	WOOD GLAZ	88	WOOD GLAZ	11A13	11A13	11A13		88
89	WOOD GLAZ	89	WOOD GLAZ	11A13	11A13	11A13		89
90	WOOD GLAZ	90	WOOD GLAZ	11A13	11A13	11A13		90
91	WOOD GLAZ	91	WOOD GLAZ	11A13	11A13	11A13		91
92	WOOD GLAZ	92	WOOD GLAZ	11A13	11A13	11A13		92
93	WOOD GLAZ	93	WOOD GLAZ	11A13	11A13	11A13		93
94	WOOD GLAZ	94	WOOD GLAZ	11A13	11A13	11A13		94
95	WOOD GLAZ	95	WOOD GLAZ	11A13	11A13	11A13		95
96	WOOD GLAZ	96	WOOD GLAZ	11A13	11A13	11A13		96
97	WOOD GLAZ	97	WOOD GLAZ	11A13	11A13	11A13		97
98	WOOD GLAZ	98	WOOD GLAZ	11A13	11A13	11A13		98
99	WOOD GLAZ	99	WOOD GLAZ	11A13	11A13	11A13		99
100	WOOD GLAZ	100	WOOD GLAZ	11A13	11A13	11A13		100




FRAME TYPES NOTE: REFER TO WINDOW SCHEDULE FOR SPECIFIC WINDOW FRAME TYPES

DOOR TYPES SCALE: 1/4" = 1'-0"



WINDOW TYPES SCALE: 1/4" = 1'-0"



WINDOW SCHEDULE

CLASS SCHEDULE

















DOOR SCHEDULE

DETAILS

FRAME

HURDLES

NO	WIDTH	HEIGHT	THICK	TYPE	MATERIAL	FRAME	GLASS	HEAD	JAMB	SILL	THE	MATERIAL	FRAME	HURDLES	REMARKS
1	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-1	WOOD	WOOD	21 5/8"	
2	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-2	WOOD	WOOD	21 5/8"	
3	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-3	WOOD	WOOD	21 5/8"	
4	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-4	WOOD	WOOD	21 5/8"	
5	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-5	WOOD	WOOD	21 5/8"	
6	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-6	WOOD	WOOD	21 5/8"	
7	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-7	WOOD	WOOD	21 5/8"	
8	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-8	WOOD	WOOD	21 5/8"	
9	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-1	WOOD	WOOD	21 5/8"	
10	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-2	WOOD	WOOD	21 5/8"	
11	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-3	WOOD	WOOD	21 5/8"	
12	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-4	WOOD	WOOD	21 5/8"	
13	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-5	WOOD	WOOD	21 5/8"	
14	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-6	WOOD	WOOD	21 5/8"	
15	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-7	WOOD	WOOD	21 5/8"	
16	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-8	WOOD	WOOD	21 5/8"	
17	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-1	WOOD	WOOD	21 5/8"	
18	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-2	WOOD	WOOD	21 5/8"	
19	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-3	WOOD	WOOD	21 5/8"	
20	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-4	WOOD	WOOD	21 5/8"	
21	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-5	WOOD	WOOD	21 5/8"	
22	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-6	WOOD	WOOD	21 5/8"	
23	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-7	WOOD	WOOD	21 5/8"	
24	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-8	WOOD	WOOD	21 5/8"	
25	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-1	WOOD	WOOD	21 5/8"	
26	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-2	WOOD	WOOD	21 5/8"	
27	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-3	WOOD	WOOD	21 5/8"	
28	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-4	WOOD	WOOD	21 5/8"	
29	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-5	WOOD	WOOD	21 5/8"	
30	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-6	WOOD	WOOD	21 5/8"	
31	36"	78"	1 1/2"	WOOD	WOOD	WOOD	WOOD	11A13	11A13	11A13	F-7	WOOD	WOOD	21 5/8"	
32	36"</														




DOOR JAMB 13 DOOR HEAD - JAMB 14 DOOR HEAD - JAMB DETAIL 15 HEAD - JAMB DETAIL 16


7.2
A

WINDOW SCHEDULE
TAYLORSVILLE FIRE STATION
 5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH
 DRAWN BY BILL GOULD
 CHECKED BY CLA
 JOB NO. 242
 DATE MARCH 30, 1988


PASKER GOULD AMES & WEAVER
 ARCHITECTS PLANNERS
 5263 SOUTH 300 WEST MURRAY, UTAH (801) 265-4669




ROLL-UP DOOR JAMB
SCALE: 3/8" = 1'-0"




RADIUS WINDOW HEAD DETAIL
SCALE: 1/4" = 1'-0"




DOOR SILL
SCALE: 3/8" = 1'-0"




DOOR SILL
SCALE: 3/8" = 1'-0"




SILL DETAIL
SCALE: 3/8" = 1'-0"




WINDOW HEAD DETAIL
SCALE: 3/8" = 1'-0"




WINDOW JAMB DETAIL
SCALE: 3/8" = 1'-0"




WINDOW SILL DETAIL
SCALE: 3/8" = 1'-0"




WINDOW HEAD DETAIL
SCALE: 3/8" = 1'-0"




WINDOW HEAD / JAMB DETAIL
SCALE: 3/8" = 1'-0"




WINDOW SILL DETAIL
SCALE: 3/8" = 1'-0"




WINDOW SILL DETAIL
SCALE: 3/8" = 1'-0"




WINDOW DETAIL
SCALE: 3/8" = 1'-0"



WINDOW DETAIL
SCALE: 3/8" = 1'-0"



WINDOW SILL DETAIL
SCALE: 3/8" = 1'-0"




WINDOW DETAIL
SCALE: 3/8" = 1'-0"




PASKER GOULD AMES & WEAVER
ARCHITECTS PLANNERS
5263 SOUTH 300 WEST
MURRAY, UTAH (801) 266-4669

DETAILS
TAYLORSVILLE FIRE STATION
5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH



DRAWN BY
BILL GOULD
CHECKED BY
CLA
JOB NO.
2104
DATE
MARCH 20, 2014




REFLECTED CEILING PLAN
 SCALE: 1/8" = 1'-0"
 NOTE:
 ALL CEILING HEIGHTS ARE 9'-0"
 UNLESS OTHERWISE NOTED.

1
 NORTH

CEILING LEGEND

- 1) 2x4 ACoustICAL PANEL CEILING SYSTEM
 2x4 Lx4 Lx4 LIGHT FRAME
 2x4 Lx4 Lx4
 2x4 Lx4 Lx4
 2x4 Lx4 Lx4
- 2) PAINTED EXPOSED STEEL STRUCTURE
 PAINTED STEEL JOIST
 PAINTED STEEL GIRTS
 STEEL LIGHT FRAME
 SEE ELECTRICAL
 PAINTED STEEL DECK
- 3) CERAMIC TILE CEILING
 6" x 6" AZO CEILING TILE
 RECESSED LIGHT FRAME
- 4) PAINTED GYPSUM BOARD CEILING
 PAINTED GYPSUM BOARD
 RECESSED LIGHT FRAME
- 5) G.I.S. SHEET
 G.I.S. SHEET
- 6) FIRE RATED WALLS
 ONE HOUR FIRE RATED
 WALLS
 SEE ELECTRICAL
 SEE MECHANICAL
 SEE MECHANICAL
 SEE MECHANICAL




REFLECTED CEILING PLAN
TAYLORSVILLE FIRE STATION
 5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH


DRAWN BY
 BELL GOULD
 CHECKED BY
 CLA
 JOB NO.
 204
 DATE
 MARCH 30, 1994

PASKER GOULD AMES & WEAVER
 ARCHITECTS PLANNERS
 5263 SOUTH 300 WEST MURRAY, UTAH (801) 265-4669





ROOF PLAN
 SCALE: 1/8" = 1'-0"
 1. SEE GENERAL NOTES TO DRAWING BOOK
 2. SEE ARCHITECT'S RECORD FOR THE CORRELATION OF THE ROOF PLAN WITH THE GENERAL NOTES TO THE DRAWING BOOK
 3. SEE ARCHITECT'S RECORD FOR THE CORRELATION OF THE ROOF PLAN WITH THE GENERAL NOTES TO THE DRAWING BOOK
 4. SEE ARCHITECT'S RECORD FOR THE CORRELATION OF THE ROOF PLAN WITH THE GENERAL NOTES TO THE DRAWING BOOK




ROOF PLAN
TAYLORSVILLE FIRE STATION
 5321 SOUTH 2100 WEST TAYLORSVILLE, UTAH


DRAWN BY
 01/18/18
 CHECKED BY
 CLA
 JOB NO.
 2104
 DATE
 MARCH 30, 1998

PASKER GOULD AMES & WEAVER
 ARCHITECTS PLANNERS
 5263 SOUTH 300 WEST
 MURRAY, UTAH (801) 266-4669







1 ROOF EAVE DETAIL
SCALE: 1/2" = 1'-0"




5 RIDGE VENT DETAIL
SCALE: 1/2" = 1'-0"




9 ROOF EAVE AND GUTTER DETAIL
SCALE: 1/2" = 1'-0"




2 ROOF EAVE DETAIL
SCALE: 1/2" = 1'-0"




6 RIDGE VENT DETAIL
SCALE: 1/2" = 1'-0"




10 ROOF EAVE AND GUTTER DETAIL
SCALE: 1/2" = 1'-0"




3 ROOF EAVE DETAIL
SCALE: 1/2" = 1'-0"




7 RIDGE VENT DETAIL
SCALE: 1/2" = 1'-0"




11 TYPICAL ROOF PENETRATION FLASHING DETAIL
SCALE: 1/2" = 1'-0"




4 RIDGE VENT DETAIL
SCALE: 1/2" = 1'-0"




8 EAVE AND GUTTER DETAIL
SCALE: 1/2" = 1'-0"




12 FRONT VIEW OF EAVE VENT DETAIL
SCALE: 1/2" = 1'-0"



13 DOWNSPOUT DETAIL
SCALE: 1/2" = 1'-0"



14 FLASHING DETAIL
SCALE: 1/2" = 1'-0"



15 ROOF EDGE AT OVERHANG / MOMENT FRAME
SCALE: 1/2" = 1'-0"



PASKER GOULD AMES & WEAVER
ARCHITECTS PLANNERS
5283 SOUTH 300 WEST
MURRAY, UTAH (801) 266-4669

ROOF DETAILS
TAYLORSVILLE FIRE STATION
5321 SOUTH 2700 WEST TAYLORSVILLE, UTAH
DRAIN BY BILL GOULD
CHECKED BY CL
JOB NO. 204
DATE MARCH 30, 1991

